

September 14, 2021

Freddy Ascuntar  
Keith & Associates  
301 East Atlantic Boulevard  
Pompano Beach, FL 33060

Subject: **WATER AND WASTEWATER CAPACITY AVAILABILITY LETTER**  
**City of Ft Lauderdale Police Headquarters – DRC Case No. UDP-S21029**  
**1300 W Broward Blvd, Fort Lauderdale, FL 33312**

Dear Freddy Ascuntar,

According to the information submitted, the project consists of replacing an 87,000 SF office and 4 condominium apartments with a 222,000 mixed use warehouse and 191,000 SF office building. There are proposed water and sewer connections to City of Fort Lauderdale (City) utilities along SW 12<sup>th</sup> avenue and Broward Boulevard. This project lies within the City's Pump Station (PS) A-4 basin and will increase the average day water demand by approximately 0.0334 million gallons per day (MGD) and the average day sewer demand by approximately 0.0253 MGD. The existing water and sewer infrastructure have the capacity to support the proposed development and no improvements are needed.

If there are changes to the proposed development after issuance of this capacity availability letter, the Owner or Owner's authorized representative shall submit a revised request based on the updated plans. Failure to seek approval prior to changing the plans may result in revocation of permit and capacity allocation. The determination of capacity availability is based upon tools and data analysis as of the date of this letter. Availability of capacities, as calculated in the attached analysis, is not guaranteed and no existing system capacity shall be considered "committed" for this project until a permit has been issued and all fees have been paid. The City reserves the right to re-evaluate the availability of capacities at the time of permit application. If sufficient capacities are not available, the City may deny the permit application or ask the Owner/Developer to submit an alternate design prior to approval. Information contained in this letter will expire one year from the date issued.

Should you have any questions or require any additional information, please contact me at (954) 828-6982.



Dronix Suarez, E.I.  
Project Manager II

Enclosures: Water and Wastewater Capacity Analysis

cc: Alan Dodd, P.E., Public Works Director  
Talal Abi-Karam, P.E., Assistant Public Works Director  
Omar Castellon, P.E., Chief Engineer  
Dennis Girisgen, P.E., City Engineer  
File: Water and Sewer Capacity Letters

**PUBLIC WORKS DEPARTMENT**

100 N. ANDREWS AVE, FORT LAUDERDALE, FLORIDA 33301  
TELEPHONE (954) 828-5772, FAX (954) 828-5074

[WWW.FORTLAUDERDALE.GOV](http://WWW.FORTLAUDERDALE.GOV)

Equal Opportunity Employer

Printed On Recycled Paper. 

City of Fort Lauderdale  
Public Works Department  
Water and Wastewater Capacity Analysis

**City of Ft Lauderdale Police Headquarters – DRC Case No. UDP-S21029  
1300 W Broward Blvd, Fort Lauderdale, FL 33312**

**PROJECT AND DESCRIPTION**

The project consists of replacing an 87,000 SF office and 4 condominium apartments with a 222,000 mixed use warehouse and 191,000 SF office building.

**DESCRIPTION OF EXISTING UTILITIES**

**Water:** The site is currently served by an 8-inch water main along West Broward boulevard and a 6-inch water main along Seminole avenue, north and east of the project site respectively. See Figure 1.

**Wastewater:** The site is currently served by a 10-inch and 8-inch gravity sewer mains to the north and east of the project site along West Broward Boulevard and Seminole Avenue. See Figure 2.

**Pumping Station:** The site is served by PS A-4 which is located within the site.

**SUMMARY OF ANALYSIS AND REQUIRED ACTION**

The existing infrastructure has the capacity to support the proposed development. Therefore, no improvements are needed.

**PUBLIC WORKS DEPARTMENT**

100 N. ANDREWS AVE, FORT LAUDERDALE, FLORIDA 33301  
TELEPHONE (954) 828-5772, FAX (954) 828-5074


[WWW.FORTLAUDERDALE.GOV](http://WWW.FORTLAUDERDALE.GOV)

Equal Opportunity Employer

Printed On Recycled Paper. 



Figure 1 – City Water Atlas



PUBLIC WORKS DEPARTMENT  
100 N. ANDREWS AVE, FORT LAUDERDALE, FLORIDA 33301  
TELEPHONE (954) 828-5772, FAX (954) 828-5074

Equal Opportunity Employer


WWW.FORTLAUDERDALE.GOV

Printed On Recycled Paper.





Figure 2 – City Sewer Atlas



**PUBLIC WORKS DEPARTMENT**  
 100 N. ANDREWS AVE, FORT LAUDERDALE, FLORIDA 33301  
 TELEPHONE (954) 828-5772, FAX (954) 828-5074  
[WWW.FORTLAUDERDALE.GOV](http://WWW.FORTLAUDERDALE.GOV)

Equal Opportunity Employer

Printed On Recycled Paper.

**WATER CAPACITY ANALYSIS**

**Requested Demand:** Based on the applicant’s site plan and building use information, the estimated average day potable water demand is approximately 33374 gallons per day (GPD), which equates to 0.0334 MGD. Average day water use demands are calculated by reducing the calculated max day water use demands by a factor of 1.3 as determined in the City’s Comprehensive Utility Strategic Master Plan. The max day water use demands are calculated using the City’s Guidelines for the Calculations of Sanitary Sewer Connection Fees and are based on City Ordinance No. C-19-29.

**Evaluation of impact on existing distribution pipe (condition & capacity):** According to the site plan, the applicant is proposing to utilize the 8 inch and 6-inch water mains along West Broward boulevard and along Seminole avenue respectively. The InfoWater hydraulic model was analyzed to determine the impact of this project on the existing 8-inch and 6-inch water mains.

**Evaluation of impact of Permitted Water Plant Capacity:** The Fiveash and the Peele Dixie Water Treatment Plants are designed to treat 70 MGD and 12 MGD of raw water respectively (82 MGD total). The total permitted Biscayne aquifer water withdrawals for these plants is limited to 52.55 MGD per the South Florida Water Management District (SFWMD) permit number 06-00123-W.

The current twelve-month rolling average production at the two plants is 38.40 MGD. The previously committed demand from development projects in the permitting or the construction stage is 4.78 MGD. Combining these figures with the demand from the proposed project of 0.0334 MGD, the required production would be 43.22 MGD. This is less than the allowable withdrawal limit of 52.55 MGD. Therefore, the water plants have sufficient capacity to serve this project. See Figure 3 below.

**Recommended Water Infrastructure Improvements:** No improvements required.




Figure 3

**WASTEWATER CAPACITY ANALYSIS**

**Requested Demand:** Based on the applicant’s site plan and building use information, the estimated average day sewer use demand is approximately 25309 GPD, which equates to 0.0253 MGD. Average day sewer use demands are calculated using the City’s Guidelines for the Calculations of Sanitary Sewer Connection Fees and are based on City Ordinance No. C-19-29.

**Evaluation of impact on existing collection pipe (condition and capacity):** According to the site plan, the applicant is proposing to utilize the 8-inch and 6-inch gravity sewer mains to the north and east of the project site along West Broward Boulevard and Seminole Avenue. Manual of Practice (MOP) 60, published by American Society of Civil Engineers (ASCE) for the gravity sewer design and used by the City staff, recommends that pipe diameters 15-inch or less be designed to flow half full during peak flows. The City uses a peak hourly flow factor of 3.0. Accounting for existing flows and based on the tools and information available to the City staff, it has been calculated that the pipes downstream of the proposed development will flow less than the ASCE-recommended 70% during peak flows. Therefore, the pipes downstream of the developments are adequate to serve the project.

**Evaluation of impact on pumping station:** PS A-4 has a duty point of 350 gallons per minute (GPM) and has a Nominal Average Pumping Operating Time (NAPOT) of approximately 4.95 hours per day. Based on projected sewage flows, the pumping run times would increase approximately 72 minutes per day. Additionally, there are other committed flows from proposed developments within the PS A-4 basin resulting in no additional runtime. PS A-4 will have a NAPOT of 6.11 hours once the proposed developments are complete, less than the recommended average of 10 hours per day. See Figure 4 below.




Figure 4



**Evaluation of impact of Permitted Wastewater Plant Capacity:** The City of Fort Lauderdale owns and operates the George T. Lohmeyer Regional Wastewater Treatment Plant (GTL), which provides wastewater treatment for the City of Fort Lauderdale. The Broward County’s Environmental Protection and Growth Management Department’s (EPGMD) Environmental Licensing & Building Permitting Division’s licensed capacity for GTL is 48 MGD-AADF (Million Gallons per Day – Annual Average Daily Flow). The annual average daily flow (AADF) to the plant is 40.67 MGD. Combining the committed flows for previously approved projects of 4.62 MGD plus the 0.0253 MGD net contribution from the project results in a total projected flow of 45.31 MGD. This is less than the permitted treatment plant capacity of 48 MGD. Therefore, the treatment plant has sufficient capacity to serve this project. See Figure 5 below.

**Recommended Wastewater Infrastructure Improvements:** No improvements required.




Figure 5

**PUBLIC WORKS DEPARTMENT**

100 N. ANDREWS AVE, FORT LAUDERDALE, FLORIDA 33301  
TELEPHONE (954) 828-5772, FAX (954) 828-5074

[WWW.FORTLAUDERDALE.GOV](http://WWW.FORTLAUDERDALE.GOV)

Equal Opportunity Employer

Printed On Recycled Paper.