

Pre-Demolition Asbestos and Lead Paint Survey Report

Aquatic Center – East & West Buildings
501 Seabreeze Blvd.
Fort Lauderdale, Florida 33316

April 12, 2022
Terracon Project No. 34217235



Prepared for:
CGHP Development, LLC
Boca Raton, Florida

Prepared by:
Terracon Consultants, Inc.
Fort Lauderdale, Florida



April 12, 2022

CGHP Development, LLC
55 NE 5th Avenue
Boca Raton, Florida 33432

Attn: Mr. Kevin Curry, Project Superintendent
Tel: 305 763 2181
E: kcurry@henselphelps.com

Re: Pre-Demolition Asbestos and Lead Paint Survey Report
Aquatic Center – East & West Buildings
501 Seabreeze Blvd.
Fort Lauderdale, Florida 33316
Terracon Project No: 34217235

Dear Mr. Curry:

Terracon Consultants, Inc. (Terracon) is pleased to submit the attached report to CGHP Development, LLC. The purpose of this report is to present the results of an asbestos and paint containing lead (PCL) survey performed on March 30, 31 and April 1, 2022 at the above referenced buildings in Fort Lauderdale, Florida. This survey was conducted in general accordance with Terracon Proposal No. P34217235 dated March 2, 2022. We understand that this survey was requested due to scheduled demolition of the Aquatic Center – East & West buildings.

Asbestos was identified in the samples collected and analyzed for this project. Please refer to the attached report for details.

At the client's request, no samples were collected from the roof or the restroom mirrors of the East building at the time of inspection. Therefore, roofing and mirrors are assumed to be asbestos-containing until the materials can be proven otherwise through sampling and analysis.

Lead containing paint was detected above the laboratory reporting limit. Please refer to the attached report for details.

- L4 – White Metal Door Frames- West Building
- L16 – Green Interior Metal Staircase- East Building



Terracon Consultants, Inc. 5371 NW 33rd Avenue, Suite 201 Fort Lauderdale, Florida 33309
P [954] 741 8282 F [954] 741 8240 terracon.com

Pre-Demolition Asbestos and Lead Paint Survey Report
Aquatic Center – East & West Buildings ■ Fort Lauderdale, Florida
April 12, 2022 ■ Terracon Project No. 34217235



Terracon appreciates the opportunity to provide this service to CGHP Development, LLC. If you have any questions regarding this report, please contact Mr. Sergio A. Adasme 954.741-8282.

Sincerely,

Terracon Consultants, Inc.
Florida Asbestos Business License Number ZA-337

A handwritten signature in blue ink, appearing to read 'S. Adasme'.

Sergio A. Adasme
Environmental Services
Project Industrial Hygienist

A handwritten signature in black ink, appearing to read 'Tom Holley'.

Tom Holley, CHMM, CIH, CSP, MRSA
Licensed Asbestos Consultant AX75
Senior Industrial Hygienist



TABLE OF CONTENTS

1.0	INTRODUCTION	1
1.1	Project Objective	1
1.2	Reliance	2
2.0	BUILDING DESCRIPTION	2
3.0	FIELD ACTIVITIES	2
3.1	Asbestos	3
3.2	Lead Paint.....	5
4.0	REGULATORY OVERVIEW	6
4.1	Asbestos	6
4.2	Lead in Construction.....	7
5.0	FINDINGS AND RECOMMENDATIONS.....	8
6.0	LIMITATIONS/GENERAL COMMENTS	10

APPENDIX A: ASBESTOS ANALYTICAL LABORATORY RESULTS

APPENDIX B: PCL ANALYTICAL LABORATORY RESULTS

APPENDIX C: LICENSES AND CERTIFICATIONS

PRE-DEMOLITION ASBESTOS AND LEAD PAINT SURVEY REPORT

Aquatic Center – East & West Buildings
501 Seabreeze Blvd.
Fort Lauderdale, Florida 33316

Terracon Project No. 34217235
April 12, 2022

1.0 INTRODUCTION

Terracon performed an asbestos and lead paint survey on March 30, 31 and April 1, 2022 at the Aquatic Center – East & West buildings located at 501 Seabreeze in Fort Lauderdale, Florida. The survey was performed at your request to assess potential hazardous materials that may be present to accommodate the planned demolition activities on the buildings.

The assessment was conducted by Terracon's State of Florida approved asbestos building inspectors Mr. Ryan Nanan and Mr. Marcello Meneses. Terracon applicable licenses and certifications are presented in Appendix C.

Building components were surveyed and homogeneous areas of suspect asbestos-containing materials (ACM) and paint containing lead (PCL) were visually identified and documented. Although reasonable effort was made to survey accessible suspect materials, additional suspect but un-sampled materials could be located in walls, in voids, below the ground or in other concealed areas. Suspect ACM samples were collected in general accordance with the sampling protocols outlined in EPA regulation 40 CFR 763 (Asbestos Hazard Emergency Response Act, AHERA). Asbestos samples were delivered to an accredited laboratory for analysis. Suspect ACM samples were analyzed by Polarized Light Microscopy. Suspect PCL samples were obtained from representative surfaces potentially containing lead containing coatings. Lead paint samples were delivered to an accredited laboratory for analysis by Flame Atomic Absorption.

1.1 Project Objective

We understand this asbestos survey was requested due to the planned demolition of the Aquatic Center – east & west buildings to satisfy requirements of the USEPA regulation 40 CFR 61, Subpart M, National Emission Standards for Hazardous Air Pollutants (NESHAP). NESHAP regulations prohibit the release of asbestos fibers to the atmosphere during renovation or demolition activities. The asbestos NESHAP requires

that potentially regulated ACM (RACM) be identified, classified and quantified prior to planned disturbances or demolition activities.

In addition, PCL samples were obtained to identify potential exposures sources, regulated by the Occupational Safety and Health Administration (OSHA) 29 CFR 1926.62 and other applicable EPA regulations that could develop if coatings are disturbed during planned demolition activities.

1.2 Reliance

This report is for the exclusive use of CGHP Development, LLC for the project being discussed. Reliance by any other party on this report is prohibited without written authorization of Terracon and CGHP Development, LLC. Reliance on this report by CGHP Development, LLC and all authorized parties will be subject to the terms, conditions, and limitations stated in the proposal, this report and Terracon's Agreement for Services. The limitations of liability defined in Terracon's Agreement for Services is the aggregate limit of Terracon's liability to CGHP Development, LLC.

2.0 BUILDING DESCRIPTION

Both 2 story buildings are comprised of concrete block/stucco with black and grey built-up roofing and a single ply roof. According to the Broward County Property Appraiser, construction date is reported to be in 1967. The Interior finishes consist of lay-in ceiling tiles, drywall and joint compound ceilings, stucco ceilings, drywall and joint compound walls, plaster walls, ceramic floor tiles, ceramic wall tiles, vinyl floor tiles, rubber flooring and carpet.

At the client's request, no samples were collected from the roof or the restroom mirrors of the East building at the time of inspection. Therefore, roofing and mirrors are assumed to be asbestos-containing until the materials can be proven otherwise through sampling and analysis.

3.0 FIELD ACTIVITIES

The survey was conducted in general accordance with the sample collection protocols established in USEPA AHERA regulations 40 CFR 763.86. Paint chip sampling for lead was conducted on observed painted surfaces located within the surveyed areas. A summary of survey activities is provided below.

3.1 Asbestos

Survey activities were initiated with visual observations of the interior materials in the designated area of the buildings to identify homogeneous areas of suspect ACM. A homogeneous area (HA) consists of building materials that appear similar throughout in terms of color and texture with consideration given to the date of application. Exterior assessment was conducted in visually accessible areas of the buildings.

A physical assessment of each homogeneous area of suspect ACM was conducted to assess the friability and condition of the materials. A friable material is defined by the EPA as a material which can be crumbled, pulverized or reduced to powder by hand pressure when dry. Friability was assessed by physically touching suspect materials.

Based on results of the visual observation, bulk samples of suspect ACM were collected in general accordance with AHERA sampling protocols. Samples of suspect materials were collected randomly selected locations in each homogeneous area. Bulk samples were collected using wet methods as applicable to reduce the potential for fiber release. Samples were placed in sealable containers and labeled with unique sample numbers using an indelible marker.

The selection of sample locations and frequency of sampling were based on Terracon's observations and the assumption that like materials in the same area are homogeneous in content. Seventy-three (73) bulk samples were collected from twenty-three (23) homogeneous areas of suspect ACM in the East building and one hundred fifty-three (153) bulk samples were collected from forty-eight (48) homogeneous areas of suspect ACM in the West building. A listing of suspect ACM observed and samples during the survey is provided below:

East Building

- Exterior Stucco
- Exterior Green Ceramic Wall Tile, Grout and Thin Set
- Exterior Multicolor 1"x1" Ceramic Wall Tile, Grout and Thin Set
- Exterior Concrete Walkway
- Exterior Grey Concrete Walkway Joint Caulking
- Interior Drywall and Joint Compound
- Perimeter Drywall and Joint Compound
- Brown 3"x36" Wood Pattern Vinyl Floor Tile and Clear Glue
- Blue 4'x6' Rubber Flooring and Brown Glue
- Drywall and Joint Compound Ceiling
- White 2'x2' Worm Ceiling Tile
- White 6"x6" Ceramic Wall Tile, Grout and Thin Set
- Grey/Blue Carpet and Brown Glue

Pre-Demolition Asbestos and Lead Paint Survey Report

Aquatic Center – East & West Buildings ■ Fort Lauderdale, Florida

April 12, 2022 ■ Terracon Project No. 34217235



- Black/White 16"x16" Ceramic Floor Tile, Grout and Thin Set
- White 2"x2" Ceramic Wall Tile, Grout, Thin Set and Brown Glue
- Teal 2"x2" Ceramic Wall Tile, Grout, Thin Set and Brown Glue
- Off White 2"x2" Ceramic Floor Tile, Grout, Thin Set and Brown Glue
- Dark Brown 2"x2" Ceramic Floor Tile, Grout, Thin Set and Brown Glue
- White / Black 2"x2" Ceramic Wall Tile, Grout, Thin Set and Brown Glue
- Red Fire Putty
- Brown Sprayed on Wall Insulation
- Grey Mastic on Metal HVAC Ducts
- Black 12"x12" Ceramic Floor Tile Thin Set and Brown Glue

West Building

- Roof Field- Main Roof
- Roof Vents- Main Roof
- Roof Drains- Main Roof
- Roof Hatch- Main Roof
- Roof Field- North Roof
- Roof Vents- North Roof
- Roof Drains- North Roof
- Roof Hatch- North Roof
- Roof Field- West Roof
- Roof Vents- West Roof
- Roof Drains- West Roof
- White Roof Caulking- West Roof
- Roof Field- South Roof
- Roof Vents- South Roof
- White Roof Caulking- South Roof
- Roof Field- Elevator Roof
- Exterior Stucco Wall
- Exterior Decorative Stone Wall
- Exterior Concrete Walkway
- Exterior 4"x4" Ceramic Wall Tile and Thin Set
- Exterior White/Grey Window Caulking
- Grey 2'x2' Rough Ceiling Tile
- White 2'x4' Worm Ceiling Tile
- Perimeter Drywall and Joint Compound
- Interior Drywall and Joint Compound
- White 12"x12" Dotted Ceiling Tile
- Drywall and Joint Compound Ceiling
- Green 4"x4" Ceramic Wall Tile, Grout and Thin Set

Pre-Demolition Asbestos and Lead Paint Survey Report

Aquatic Center – East & West Buildings ■ Fort Lauderdale, Florida

April 12, 2022 ■ Terracon Project No. 34217235



- Beige 4"x4" Ceramic Wall Tile, Grout and Thin Set
- White 4" Baseboard and Brown Glue
- Grey 12"x12" Vinyl Floor Tile and Brown Glue over Grey 12"x12" Vinyl Floor Tile and Black Mastic
- Green Carpet and Brown Glue
- Pink Carpet and Brown Glue
- Perimeter Plaster and Drywall
- Grey 12"x12" Vinyl Floor Tile and Brown Glue over Brown 12"x12" Vinyl Floor Tile and Black Mastic
- Brown Wood Pattern 4"x36" Vinyl Floor Plank
- Brown 12"x12" Ceramic Floor Tile, Grout, Thin Set and Black Mastic
- White Fiber Glass Reinforced Panel and Brown Glue
- Black Mastic on HVAC Ducts
- Brown/White 1"x1" Ceramic Floor Tile, Grout and Thin Set
- Grey Sink Undercoating
- Grey 4"x4" Ceramic Wall/Floor Tile, Grout and Thin Set
- Pink 4"x4" Ceramic Wall/Floor Tile, Grout and Thin Set
- Interior Stucco Ceiling
- Brown Wood Pattern 6"x48" Ceramic Floor Tile, Grout, Thin Set and Brown Glue
- White 12"x12" Holes Ceiling Tile and Brown Glue
- Stone and Mortar Staircase
- Black Mirror Mastic

Bold indicates asbestos

Bulk samples were submitted under chain of custody to EMLab P&K of Fort Lauderdale, Florida for analysis by PLM per EPA methodology EPA/600/R-93/116. The percentage of asbestos, where applicable, was determined by microscopic visual estimation. EMLab P&K is accredited under the National Voluntary Laboratory Accreditation Program (NVLAP Accreditation No. 200738-0).

3.2 Lead Paint

Terracon performed a visual assessment of the interior and exterior of the buildings to identify, locate and assess predominant painted surfaces for lead. Representative paint chip samples were chosen from each unique combination of paint color, component and substrate.

A total of twenty-three paint chips samples were collected and submitted to EMLab P&K of Tustin, California for analysis. The paint chips were analyzed by Flame Atomic Absorption Spectrometry (AAS) by NIOSH 7082 and EPA method 7000B Modified.

EMLab P&K is accredited under the Environmental Lead Laboratory Accreditation Program (AIHA-LAP, Accreditation No. 178697). A listing of suspect lead paint observed and sampled during the survey is provided below:

- White Exterior Stucco- West Building
- White Drywall and Joint Compound Walls- West Building
- White Plaster Walls- West Building
- White Metal Door Frames- West Building
- White Wood Doors- West Building
- Green Metal Display Racks- West Building
- Blue Metal Display Racks- West Building
- Pink Drywall and Joint Compound Walls- West Building
- Grey Drywall and Joint Compound Walls- West Building
- White Exterior Stucco- East Building
- Pink Exterior Stucco- East Building
- Black Exterior Concrete Columns- East Building
- Green Exterior Metal Window Frame- East Building
- Grey Exterior Concrete Walls- East Building
- Blue Exterior Stucco Ceiling- East Building
- Green Interior Metal Staircase- East Building
- White Drywall and Joint Compound Walls and Ceilings- East Building
- White Metal Door Frames- East Building
- White Wood Doors- East Building
- White Interior Concrete Block and Mortar Walls- East Building
- Yellow Metal Display Racks- East Building
- Blue Metal Display Racks- East Building
- Green Metal Display Racks- East Building

Bold indicates lead

4.0 REGULATORY OVERVIEW

4.1 Asbestos

The asbestos NESHAP (40 CFR Part 61, Subpart M) regulates asbestos fiber emissions and asbestos waste disposal practices. It also requires the identification and classification of existing building materials prior to demolition or renovation activity. Under NESHAP, asbestos-containing building materials are classified as either friable, Category I non-friable or Category II non-friable ACM. Friable materials are those that, when dry, may be crumbled, pulverized or reduced to powder by hand pressure. Category I non-friable ACM includes packings, gaskets, resilient floor coverings and asphalt roofing products containing more than 1% asbestos. Category II non-friable

ACM are any materials other than Category I materials that contain more than 1% asbestos.

Friable ACM, Category I and Category II non-friable ACM which is in poor condition and has become friable or which will be subjected to drilling, sanding, grinding, cutting or abrading and which could be crushed or pulverized during anticipated renovation or demolition activities are considered regulated ACM (RACM).

In the State of Florida, asbestos activities are regulated by the Florida Department of Environmental Protection (FDEP). RACM must be removed prior to renovation or demolition activities which will disturb the materials. The owner or operator must provide the FDEP with written notification of planned removal activities at least 10 working days prior to the commencement of asbestos abatement activities. Removal of RACM must be conducted by a State of Florida-licensed asbestos abatement contractor.

The OSHA Asbestos standard for construction (29 CFR 1926.1101) regulates workplace exposure to asbestos. The OSHA standard requires that employee exposure to airborne asbestos fibers be maintained below 0.1 asbestos fibers per cubic centimeter of air (0.1 f/cc). The OSHA standard classifies construction and maintenance activities which could disturb ACM and specifies work practices and precautions which employers must follow when engaging in each class of regulated work.

4.2 Lead in Construction

Lead is regulated by the EPA, HUD, FDEP and OSHA. The EPA and FDEP regulate lead use, removal, and disposal, and OSHA regulates lead exposure to workers. The EPA and HUD, with their small child-safety focus, define Lead-Based Paint (LBP) as paint, varnish, stain, or other applied coating that contains lead equal to or greater than 1.0 mg/cm², 5,000 mg/kg, or 0.5% by dry weight as determined by laboratory analysis.

However, for the purpose of the OSHA lead standard, with its focus on the safety/exposure of construction workers, paint-containing lead includes any detectable concentrations of metallic lead, all inorganic lead compounds, and organic lead soaps. A synopsis of the OSHA regulations (29 CFR 1926.62) and the applicability are as follows:

The OSHA Lead Standard for Construction (29 CFR 1926.62) applies to all construction work where an employee may be occupationally exposed to lead. All work related to construction, alteration, or repair (including painting and decorating) is included. The lead-in-construction standard applies to any detectable concentration of lead in paint, as even small concentrations of lead can result in unacceptable

employee exposures depending upon on the method of removal and other workplace conditions.

Under this standard, construction includes, but is not limited to, the following:

- Demolition or salvage of structures where lead or materials containing lead are present
- Removal or encapsulation of materials containing lead
- New construction, alteration, repair, or renovation of structures, substrates, or portions containing lead, or materials containing lead
- Installation of products containing lead
- Lead contamination/emergency clean-up
- Transportation, disposal, storage, or containment of lead or materials containing lead on the site or location at which construction activities are performed
- Maintenance operations associated with construction activities described above

5.0 FINDINGS AND RECOMMENDATIONS

5.1 Asbestos

Asbestos was identified in the Black Mastic (10% Chrysotile) associated with the non-asbestos containing Grey 12"x12" Vinyl Floor Tile under the non-asbestos containing Grey 12"x12" Vinyl Floor Tile and Brown Glue (HA-31, Samples 31A, 31B and 31C). The floor tiles span over an area of approximately 2,300 square feet and are located on the first-floor conference room and office by the main entrance, around the main hall and storage room behind main hall in the West building. The asbestos analytical laboratory reports for PLM are provided in Appendix A.

Asbestos was identified in the Black Mastic (5% Chrysotile) associated with the non-asbestos containing Brown 12"x12" Vinyl Floor Tile under the non-asbestos containing Grey 12"x12" Vinyl Floor Tile and Brown Glue (HA-35, Samples 35A, 35B and 35C). The floor tiles span over an area of approximately 3,200 square feet and are located on the first-floor banquet hall and the restroom entrances in the banquet hall in the West building. The asbestos analytical laboratory reports for PLM are provided in Appendix A.

Asbestos was identified in the Black Mastic (5% Chrysotile) associated with the non-asbestos containing Brown 12"x12" Ceramic Floor Tile and Thin Set (HA-37, Samples 37A, 37B and 37C). The floor tiles span over an area of approximately 65 square feet and are located on the first-floor kitchen area of the banquet hall in

the West building. The asbestos analytical laboratory reports for PLM are provided in Appendix A.

Asbestos was identified in the Black HVAC Duct Mastic (5% Chrysotile) (HA-39, Samples 39A, 39B, 39C, 39D and 39E). The black duct mastic spans over an area of approximately 950 square feet and is located on the first-floor, above the ceiling of the main entrance, along the east perimeter wall of the main hall, along the interior wall over green carpeted display cases, banquet hall ceiling, south perimeter wall in banquet hall, and throughout the second-floor ceiling in the West building. The asbestos analytical laboratory reports for PLM are provided in Appendix A.

Asbestos was identified in the Black Mirror Mastic (10% Chrysotile) (HA-48, Samples 48A, 48B and 48C). The black mirror mastic spans over an area of approximately 100 square feet and is located in the second-floor restrooms and inside the mirrored elevator walls in the West building. The asbestos analytical laboratory reports for PLM are provided in Appendix A.

At the client's request, no samples were collected from the roof or the restroom mirrors of the East building at the time of inspection. Therefore, roofing and mirrors are assumed to be asbestos-containing until the materials can be proven otherwise through sampling and analysis.

5.2 Lead-Based Paint

Quantifiable concentrations of lead were identified in samples of the following paint:

Sample #s	Description	Substrate	Lead Results (ppm)
L4	White Door Frames-West Building	Metal	2200 (ppm)
L16	Green Interior Staircase-East Building	Metal	120 (ppm)

The OSHA Lead in Construction rule 29 CFR 1926.62 regulates lead exposures during the demolition or renovation of structures where lead is present. An employer is required to perform an initial determination assessment for employees involved with the disturbance of lead containing paint to determine the anticipated level of dust exposure during demolition or renovation activities.

Recommendations

Asbestos:

The results of this assessment should be communicated to the renovation contractor and other subcontractors working in the building and a copy of the survey should be on-site during renovation or demolition activities. In addition, a 10-day renovation/demolition notice may need to be sent to Broward County, Pollution Prevention Division – Air Quality. We recommend that a call be made to (954) 519-1420 to confirm their regulatory requirements.

Any concealed building materials discovered during demolition activities not identified in this report, which are suspected to contain asbestos, should be sampled by an AHERA-certified asbestos inspector and analyzed by a NVLAP-accredited laboratory to confirm the presence or absence of asbestos prior to disturbing such materials. If the materials are found to contain asbestos, various regulations (EPA NESHAP, Pollution Prevention Division, and OSHA) will apply.

Paint-Containing Lead:

With the lead detected in the east and west buildings, proper notification to the contractors as to the presence of lead coating so that the proper controls, training, work practices, etc., as delineated in the OSHA Lead in Construction standard (29 CFR 1926.62) can be implemented. In addition, the contractor should also be made aware that the disposal of lead-containing construction components may require Toxicity Characteristic Leaching Procedure (TCLP) testing. Likewise, direct contact with the FDEP Southeast District (561-681-6600) is recommended to confirm their actual regulatory requirements.

6.0 LIMITATIONS/GENERAL COMMENTS

It should be noted that suspect asbestos materials and lead paint, other than those identified during the March 30, 31 and April 1, 2022 survey may exist in locations outside of the designated surveyed areas. Should suspect materials other than those which were identified during this survey be uncovered prior to demolition activities, those materials should be assumed asbestos-containing, and/or paint-containing lead until sampling and analysis can confirm or deny their asbestos content.

Pre-Demolition Asbestos and Lead Paint Survey Report

Aquatic Center – East & West Buildings ■ Fort Lauderdale, Florida

April 12, 2022 ■ Terracon Project No. 34217235



The asbestos and PCL survey were conducted in a manner consistent with the level of care and skill ordinarily exercised by members of the profession currently practicing under similar conditions in the same locale. The results, findings, conclusions and recommendations expressed in this report are based on conditions observed during our survey of the buildings. The information contained in this report is relevant to the date on which this survey was performed and should not be relied upon to represent conditions at a later date.

This report has been prepared on behalf of and exclusively for use by HENSEL PHELPS for specific application to their project as discussed. This report is not a bidding document. Contractors or consultants reviewing this report must draw their own conclusions regarding further investigation or remediation deemed necessary. Terracon does not warrant the work of regulatory agencies, laboratories or other third parties supplying information which may have been used in the preparation of this report. No warranty, express or implied is made.

APPENDIX A

ASBESTOS ANALYTICAL LABORATORY RESULTS

Report for:

Mr. Sergio Adasme
Terracon - Fort Lauderdale, FL
5371 NW 33rd Ave.
Suite 201
Fort Lauderdale, FL 33309

Regarding: Project: Aquatic Center West Building; 501 Seabreeze Blvd. Fort Lauderdale, FL
EML ID: 2890737

Approved by:



Approved Signatory
Balu Krishnan

Dates of Analysis:

Asbestos PLM: 04-06-2022 and 04-07-2022

Service SOPs: Asbestos PLM (EPA 40CFR App E to Sub E of Part 763 & EPA METHOD 600/R-93-116, SOP EM-AS-S-1267)
NVLAP Lab Code 200738-0

All samples were received in acceptable condition unless noted in the Report Comments portion in the body of the report. The results relate only to the samples as received and tested. The results include an inherent uncertainty of measurement associated with estimating percentages by polarized light microscopy. Measurement uncertainty data for sample results with >1% asbestos concentration can be provided when requested.

Eurofins EMLab P&K ("the Company") shall have no liability to the client or the client's customer with respect to decisions or recommendations made, actions taken or courses of conduct implemented by either the client or the client's customer as a result of or based upon the Test Results. In no event shall the Company be liable to the client with respect to the Test Results except for the Company's own willful misconduct or gross negligence nor shall the Company be liable for incidental or consequential damages or lost profits or revenues to the fullest extent such liability may be disclaimed by law, even if the Company has been advised of the possibility of such damages, lost profits or lost revenues. In no event shall the Company's liability with respect to the Test Results exceed the amount paid to the Company by the client therefor.

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center West Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022

Date of Receipt: 04-04-2022

Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Total Samples Submitted:** 154**Total Samples Analyzed:** 154**Total Samples with Layer Asbestos Content > 1%:** 17**Location: 1A, Roof Field- Main Roof**

Lab ID-Version‡: 13867343-1

Sample Layers	Asbestos Content
Gray Cementitious Material	ND
Black Tar	ND
Black Roofing Shingle with Gray Pebbles	ND
Silver Coating	ND
Composite Non-Asbestos Content:	10% Glass Fibers
Sample Composite Homogeneity:	Moderate

Location: 1B, Roof Field- Main Roof

Lab ID-Version‡: 13867344-1

Sample Layers	Asbestos Content
Gray Cementitious Material	ND
Black Tar	ND
Black Roofing Shingle with Gray Pebbles	ND
Silver Coating	ND
Composite Non-Asbestos Content:	10% Glass Fibers
Sample Composite Homogeneity:	Moderate

Location: 1C, Roof Field- Main Roof

Lab ID-Version‡: 13867345-1

Sample Layers	Asbestos Content
Gray Cementitious Material	ND
Black Tar	ND
Black Roofing Shingle with Gray Pebbles	ND
Silver Coating	ND
Composite Non-Asbestos Content:	10% Glass Fibers
Sample Composite Homogeneity:	Moderate

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center West Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022

Date of Receipt: 04-04-2022

Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Location: 2A, Roof Vents- Main Roof**

Lab ID-Version‡: 13867346-1

Sample Layers	Asbestos Content
Gray Cementitious Material	ND
Black Felt	ND
Black Tar	ND
Black Roofing Shingle with Gray Pebbles	ND
Silver Coating	ND
Composite Non-Asbestos Content:	15% Glass Fibers
Sample Composite Homogeneity:	Poor

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center West Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022

Date of Receipt: 04-04-2022

Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Location: 2B, Roof Vents- Main Roof**

Lab ID-Version‡: 13867347-1

Sample Layers	Asbestos Content
Gray Cementitious Material	ND
Black Felt	ND
Black Tar	ND
Black Roofing Shingle with Gray Pebbles	ND
Silver Coating	ND
Composite Non-Asbestos Content:	15% Glass Fibers
Sample Composite Homogeneity:	Poor

Location: 2C, Roof Vents- Main Roof

Lab ID-Version‡: 13867348-1

Sample Layers	Asbestos Content
Gray Cementitious Material	ND
Black Felt	ND
Black Tar	ND
Black Roofing Shingle with Gray Pebbles	ND
Silver Coating	ND
Composite Non-Asbestos Content:	15% Glass Fibers
Sample Composite Homogeneity:	Poor

Location: 3A, Roof Drains- Main Roof

Lab ID-Version‡: 13867349-1

Sample Layers	Asbestos Content
Gray Cementitious Material	ND
Black Tar	ND
Black Roofing Shingle with Gray Pebbles	ND
Silver Coating	ND
Composite Non-Asbestos Content:	10% Glass Fibers
Sample Composite Homogeneity:	Moderate

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center West Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022
 Date of Receipt: 04-04-2022
 Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Location: 3B, Roof Drains- Main Roof**

Lab ID-Version‡: 13867350-1

Sample Layers	Asbestos Content
Gray Cementitious Material	ND
Black Tar	ND
Black Roofing Shingle with Gray Pebbles	ND
Silver Coating	ND
Composite Non-Asbestos Content:	10% Glass Fibers
Sample Composite Homogeneity:	Moderate

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center West Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022

Date of Receipt: 04-04-2022

Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Location: 3C, Roof Drains- Main Roof**

Lab ID-Version‡: 13867351-1

Sample Layers	Asbestos Content
Gray Cementitious Material	ND
Black Tar	ND
Black Roofing Shingle with Gray Pebbles	ND
Silver Coating	ND
Composite Non-Asbestos Content:	10% Glass Fibers
Sample Composite Homogeneity:	Moderate

Location: 4A, Roof Hatch- Main Roof

Lab ID-Version‡: 13867352-1

Sample Layers	Asbestos Content
Black Felt	ND
Black Tar	ND
Black Roofing Shingle with Gray Pebbles	ND
Silver Coating	ND
Composite Non-Asbestos Content:	15% Glass Fibers
Sample Composite Homogeneity:	Poor

Location: 4B, Roof Hatch- Main Roof

Lab ID-Version‡: 13867353-1

Sample Layers	Asbestos Content
Gray Cementitious Material	ND
Black Felt	ND
Black Tar	ND
Black Roofing Shingle with Gray Pebbles	ND
Silver Coating	ND
Composite Non-Asbestos Content:	15% Glass Fibers
Sample Composite Homogeneity:	Poor

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center West Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022
 Date of Receipt: 04-04-2022
 Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Location: 4C, Roof Hatch- Main Roof**

Lab ID-Version‡: 13867354-1

Sample Layers	Asbestos Content
Gray Cementitious Material	ND
Black Felt	ND
Black Tar	ND
Black Roofing Shingle with Gray Pebbles	ND
Silver Coating	ND
Composite Non-Asbestos Content:	15% Glass Fibers
Sample Composite Homogeneity:	Poor

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center West Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022

Date of Receipt: 04-04-2022

Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Location: 5A, Roof Field- North Roof**

Lab ID-Version‡: 13867355-1

Sample Layers	Asbestos Content
Gray Cementitious Material	ND
Black Tar	ND
Black Roofing Shingle with Gray Pebbles	ND
Silver Coating	ND
Composite Non-Asbestos Content:	5% Glass Fibers 5% Nylon
Sample Composite Homogeneity:	Moderate

Location: 5B, Roof Field- North Roof

Lab ID-Version‡: 13867356-1

Sample Layers	Asbestos Content
Gray Cementitious Material	ND
Black Tar	ND
Black Roofing Shingle with Gray Pebbles	ND
Silver Coating	ND
Composite Non-Asbestos Content:	5% Glass Fibers 5% Nylon
Sample Composite Homogeneity:	Moderate

Location: 5C, Roof Field- North Roof

Lab ID-Version‡: 13867357-1

Sample Layers	Asbestos Content
Gray Cementitious Material	ND
Black Tar	ND
Black Roofing Shingle with Gray Pebbles	ND
Silver Coating	ND
Composite Non-Asbestos Content:	5% Glass Fibers 5% Nylon
Sample Composite Homogeneity:	Moderate

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center West Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022
 Date of Receipt: 04-04-2022
 Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Location: 6A, Roof Vents- North Roof**

Lab ID-Version‡: 13867358-1

Sample Layers	Asbestos Content
Gray Cementitious Material	ND
Black Mastic	ND
Black Felt	ND
Black Tar	ND
Black Roofing Shingle with Gray Pebbles	ND
Silver Coating	ND
Composite Non-Asbestos Content:	10% Glass Fibers 5% Cellulose
Sample Composite Homogeneity:	Poor

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center West Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022

Date of Receipt: 04-04-2022

Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Location: 6B, Roof Vents- North Roof**

Lab ID-Version‡: 13867359-1

Sample Layers	Asbestos Content
Gray Cementitious Material	ND
Black Mastic	ND
Black Felt	ND
Silver Non-Fibrous Material (Metal Foil)	ND
Black Tar	ND
Black Roofing Shingle with Gray Pebbles	ND
Silver Coating	ND
Composite Non-Asbestos Content:	10% Glass Fibers 5% Cellulose
Sample Composite Homogeneity:	Poor

Location: 6C, Roof Vents- North Roof

Lab ID-Version‡: 13867360-1

Sample Layers	Asbestos Content
Gray Cementitious Material	ND
Black Mastic	ND
Black Felt	ND
Silver Non-Fibrous Material (Metal Foil)	ND
Black Tar	ND
Black Roofing Shingle with Gray Pebbles	ND
Silver Coating	ND
Composite Non-Asbestos Content:	10% Glass Fibers 5% Cellulose
Sample Composite Homogeneity:	Poor

Location: 7A, Roof Drains- North Roof

Lab ID-Version‡: 13867361-1

Sample Layers	Asbestos Content
White Cementitious Material	ND
Black Felt	ND
Black Tar	ND
Black Roofing Shingle with Gray Pebbles	ND
Silver Coating	ND
Composite Non-Asbestos Content:	10% Glass Fibers
Sample Composite Homogeneity:	Poor

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center West Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022

Date of Receipt: 04-04-2022

Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Location: 7B, Roof Drains- North Roof**

Lab ID-Version‡: 13867362-1

Sample Layers	Asbestos Content
White Cementitious Material	ND
Black Felt	ND
Black Tar	ND
Black Roofing Shingle with Gray Pebbles	ND
Silver Coating	ND
Composite Non-Asbestos Content:	10% Glass Fibers
Sample Composite Homogeneity:	Poor

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center West Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022

Date of Receipt: 04-04-2022

Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Location: 7C, Roof Drains- North Roof**

Lab ID-Version‡: 13867363-1

Sample Layers	Asbestos Content
Black Roofing Material	ND
Sample Composite Homogeneity:	Good

Location: 8A, Roof Hatch- North Roof

Lab ID-Version‡: 13867364-1

Sample Layers	Asbestos Content
Gray Cementitious Material	ND
Black Tar	ND
Black Roofing Shingle with Gray Pebbles	ND
Silver Coating	ND
Composite Non-Asbestos Content:	10% Glass Fibers
Sample Composite Homogeneity:	Moderate

Location: 8B, Roof Hatch- North Roof

Lab ID-Version‡: 13867365-1

Sample Layers	Asbestos Content
Gray Cementitious Material	ND
Black Tar	ND
Black Roofing Shingle with Gray Pebbles	ND
Silver Coating	ND
Composite Non-Asbestos Content:	10% Glass Fibers
Sample Composite Homogeneity:	Moderate

Location: 8C, Roof Hatch- North Roof

Lab ID-Version‡: 13867366-1

Sample Layers	Asbestos Content
Gray Cementitious Material	ND
Black Tar	ND
Black Roofing Shingle with Gray Pebbles	ND
Silver Coating	ND
Composite Non-Asbestos Content:	10% Glass Fibers
Sample Composite Homogeneity:	Moderate

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center West Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022

Date of Receipt: 04-04-2022

Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Location: 9A, Roof Field- West Roof**

Lab ID-Version‡: 13867367-1

Sample Layers	Asbestos Content
Black Roofing Shingle with Gray Pebbles	ND
Black Tar	ND
White Fibrous Material	ND
White Drywall	ND
Composite Non-Asbestos Content:	10% Glass Fibers
Sample Composite Homogeneity:	Moderate

Location: 9B, Roof Field- West Roof

Lab ID-Version‡: 13867368-1

Sample Layers	Asbestos Content
Black Roofing Shingle with Gray Pebbles	ND
Black Tar	ND
White Fibrous Material	ND
White Drywall	ND
Composite Non-Asbestos Content:	10% Glass Fibers
Sample Composite Homogeneity:	Moderate

Location: 9C, Roof Field- West Roof

Lab ID-Version‡: 13867369-1

Sample Layers	Asbestos Content
Black Roofing Shingle with Gray Pebbles	ND
Black Tar	ND
White Fibrous Material	ND
White Drywall	ND
Composite Non-Asbestos Content:	10% Glass Fibers
Sample Composite Homogeneity:	Moderate

Location: 10A, Roof Vents- West Roof

Lab ID-Version‡: 13867370-1

Sample Layers	Asbestos Content
Black Roofing Shingle with Gray Pebbles	ND
Black Tar	ND
White Fibrous Material	ND
White Drywall	ND
Composite Non-Asbestos Content:	10% Glass Fibers
Sample Composite Homogeneity:	Moderate

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center West Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022

Date of Receipt: 04-04-2022

Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Location: 10B, Roof Vents- West Roof**

Lab ID-Version‡: 13867371-1

Sample Layers	Asbestos Content
Black Roofing Shingle with Gray Pebbles	ND
Black Tar	ND
White Fibrous Material	ND
White Drywall	ND
Composite Non-Asbestos Content:	10% Glass Fibers
Sample Composite Homogeneity:	Moderate

Location: 10C, Roof Vents- West Roof

Lab ID-Version‡: 13867372-1

Sample Layers	Asbestos Content
Black Roofing Shingle with Gray Pebbles	ND
Black Tar	ND
White Fibrous Material	ND
White Drywall	ND
Composite Non-Asbestos Content:	10% Glass Fibers
Sample Composite Homogeneity:	Moderate

Location: 11A, Roof Drains- West Roof

Lab ID-Version‡: 13867373-1

Sample Layers	Asbestos Content
Black Roofing Shingle with Gray Pebbles	ND
Black Tar	ND
White Fibrous Material	ND
White Drywall	ND
Composite Non-Asbestos Content:	10% Glass Fibers
Sample Composite Homogeneity:	Moderate

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
C/O: Mr. Sergio Adasme
Re: Aquatic Center West Building; 501 Seabreeze
Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022

Date of Receipt: 04-04-2022

Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Location: 11B, Roof Drains- West Roof**

Lab ID-Version‡: 13867374-1

Sample Layers	Asbestos Content
Black Roofing Shingle with Gray Pebbles	ND
Black Tar	ND
Black Felt	ND
Black Mastic	ND
White Foam	ND
Composite Non-Asbestos Content:	15% Glass Fibers
Sample Composite Homogeneity:	Poor

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center West Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022

Date of Receipt: 04-04-2022

Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Location: 11C, Roof Drains- West Roof**

Lab ID-Version‡: 13867375-1

Sample Layers	Asbestos Content
Black Roofing Shingle with Gray Pebbles	ND
Black Tar	ND
Black Felt	ND
White Drywall	ND
Composite Non-Asbestos Content:	15% Nylon
Sample Composite Homogeneity:	Moderate

Location: 12A, White Roof Caulking- West Roof

Lab ID-Version‡: 13867376-1

Sample Layers	Asbestos Content
White Caulk	ND
Composite Non-Asbestos Content:	10% Nylon
Sample Composite Homogeneity:	Good

Location: 12B, White Roof Caulking- West Roof

Lab ID-Version‡: 13867377-1

Sample Layers	Asbestos Content
White Caulk	ND
Composite Non-Asbestos Content:	10% Nylon
Sample Composite Homogeneity:	Good

Location: 12C, White Roof Caulking- West Roof

Lab ID-Version‡: 13867378-1

Sample Layers	Asbestos Content
White Caulk	ND
Composite Non-Asbestos Content:	10% Nylon
Sample Composite Homogeneity:	Good

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center West Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022

Date of Receipt: 04-04-2022

Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Location: 13A, Roof Field- South Roof**

Lab ID-Version‡: 13867379-1

Sample Layers	Asbestos Content
Silver Coating	ND
Black Roofing Shingle with Gray Pebbles	ND
Black Tar	ND
Gray Cementitious Material	ND
Composite Non-Asbestos Content:	5% Glass Fibers
Sample Composite Homogeneity:	Moderate

Location: 13B, Roof Field- South Roof

Lab ID-Version‡: 13867380-1

Sample Layers	Asbestos Content
Silver Coating	ND
Black Roofing Shingle with Gray Pebbles	ND
Black Tar	ND
Gray Cementitious Material	ND
Composite Non-Asbestos Content:	5% Glass Fibers
Sample Composite Homogeneity:	Moderate

Location: 13C, Roof Field- South Roof

Lab ID-Version‡: 13867381-1

Sample Layers	Asbestos Content
Silver Coating	ND
Black Roofing Shingle with Gray Pebbles	ND
Black Tar	ND
Gray Cementitious Material	ND
Composite Non-Asbestos Content:	5% Glass Fibers
Sample Composite Homogeneity:	Moderate

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center West Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022
 Date of Receipt: 04-04-2022
 Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Location: 14A, Roof Vents- South Roof**

Lab ID-Version‡: 13867382-1

Sample Layers	Asbestos Content
Silver Coating	ND
Black Roofing Shingle with Gray Pebbles	ND
Black Tar	ND
Gray Cementitious Material	ND
Composite Non-Asbestos Content:	5% Glass Fibers 5% Nylon
Sample Composite Homogeneity:	Moderate

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center West Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022

Date of Receipt: 04-04-2022

Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Location: 14B, Roof Vents- South Roof**

Lab ID-Version‡: 13867383-1

Sample Layers	Asbestos Content
Silver Coating	ND
Black Roofing Shingle with Gray Pebbles	ND
Black Tar	ND
Gray Cementitious Material	ND
Composite Non-Asbestos Content:	5% Glass Fibers 5% Nylon
Sample Composite Homogeneity:	Moderate

Location: 14C, Roof Vents- South Roof

Lab ID-Version‡: 13867384-1

Sample Layers	Asbestos Content
Silver Coating	ND
Black Roofing Shingle with Gray Pebbles	ND
Black Tar	ND
Gray Cementitious Material	ND
Composite Non-Asbestos Content:	5% Glass Fibers 5% Nylon
Sample Composite Homogeneity:	Moderate

Location: 15A, White Roof Caulking- South Roof

Lab ID-Version‡: 13867385-1

Sample Layers	Asbestos Content
White Caulk	ND
Composite Non-Asbestos Content:	10% Nylon
Sample Composite Homogeneity:	Good

Location: 15B, White Roof Caulking- South Roof

Lab ID-Version‡: 13867386-1

Sample Layers	Asbestos Content
White Caulk	ND
Composite Non-Asbestos Content:	10% Nylon
Sample Composite Homogeneity:	Good

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center West Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022

Date of Receipt: 04-04-2022

Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Location: 15C, White Roof Caulking- South Roof**

Lab ID-Version‡: 13867387-1

Sample Layers	Asbestos Content
White Caulk	ND
Composite Non-Asbestos Content:	10% Nylon
Sample Composite Homogeneity:	Good

Location: 16A, Roof Field- Elevator Roof

Lab ID-Version‡: 13867388-1

Sample Layers	Asbestos Content
Silver Coating	ND
Black Roofing Shingle with Gray Pebbles	ND
Black Tar	ND
White Cementitious Material	ND
Composite Non-Asbestos Content:	5% Cellulose 5% Glass Fibers
Sample Composite Homogeneity:	Moderate

Location: 16B, Roof Field- Elevator Roof

Lab ID-Version‡: 13867389-1

Sample Layers	Asbestos Content
Silver Coating	ND
Black Roofing Shingle with Gray Pebbles	ND
Black Tar	ND
White Cementitious Material	ND
Composite Non-Asbestos Content:	5% Cellulose 5% Glass Fibers
Sample Composite Homogeneity:	Moderate

Location: 16C, Roof Field- Elevator Roof

Lab ID-Version‡: 13867390-1

Sample Layers	Asbestos Content
Silver Coating	ND
Black Roofing Shingle with Gray Pebbles	ND
Black Tar	ND
White Cementitious Material	ND
Composite Non-Asbestos Content:	5% Cellulose 5% Glass Fibers
Sample Composite Homogeneity:	Moderate

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center West Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022

Date of Receipt: 04-04-2022

Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Location: 17A, Exterior Stucco Wall**

Lab ID-Version‡: 13867391-1

Sample Layers	Asbestos Content
Gray Stucco	ND
White Paint	ND
Sample Composite Homogeneity: Good	

Location: 17B, Exterior Stucco Wall

Lab ID-Version‡: 13867392-1

Sample Layers	Asbestos Content
Gray Stucco	ND
White Paint	ND
Sample Composite Homogeneity: Good	

Location: 17C, Exterior Stucco Wall

Lab ID-Version‡: 13867393-1

Sample Layers	Asbestos Content
Gray Stucco	ND
White Paint	ND
Sample Composite Homogeneity: Good	

Location: 18A, Exterior Decorative Stone Wall

Lab ID-Version‡: 13867394-1

Sample Layers	Asbestos Content
White Non-Fibrous Material (Stone Wall)	ND
Sample Composite Homogeneity: Good	

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center West Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022

Date of Receipt: 04-04-2022

Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Location: 18B, Exterior Decorative Stone Wall**

Lab ID-Version‡: 13867395-1

Sample Layers	Asbestos Content
White Non-Fibrous Material (Stone Wall)	ND
Sample Composite Homogeneity: Good	

Location: 18C, Exterior Decorative Stone Wall

Lab ID-Version‡: 13867396-1

Sample Layers	Asbestos Content
White Non-Fibrous Material (Stone Wall)	ND
Sample Composite Homogeneity: Good	

Location: 19A, Exterior Concrete Walkway

Lab ID-Version‡: 13867397-1

Sample Layers	Asbestos Content
Gray Concrete	ND
Sample Composite Homogeneity: Good	

Location: 19B, Exterior Concrete Walkway

Lab ID-Version‡: 13867398-1

Sample Layers	Asbestos Content
Gray Concrete	ND
Sample Composite Homogeneity: Good	

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center West Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022
 Date of Receipt: 04-04-2022
 Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Location: 19C, Exterior Concrete Walkway**

Lab ID-Version‡: 13867399-1

Sample Layers	Asbestos Content
Gray Concrete	ND
Sample Composite Homogeneity: Good	

Location: 20A, Exterior 4"x4" Ceramic Wall Tile and Thin Set

Lab ID-Version‡: 13867400-1

Sample Layers	Asbestos Content
White Thinset	ND
White Ceramic Tile	ND
Sample Composite Homogeneity: Good	

Location: 20B, Exterior 4"x4" Ceramic Wall Tile and Thin Set

Lab ID-Version‡: 13867401-1

Sample Layers	Asbestos Content
White Thinset	ND
White Ceramic Tile	ND
Sample Composite Homogeneity: Good	

Location: 20C, Exterior 4"x4" Ceramic Wall Tile and Thin Set

Lab ID-Version‡: 13867402-1

Sample Layers	Asbestos Content
White Thinset	ND
White Ceramic Tile	ND
Sample Composite Homogeneity: Good	

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center West Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022

Date of Receipt: 04-04-2022

Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Location: 21A, Exterior White/Grey Window Caulking**

Lab ID-Version‡: 13867403-1

Sample Layers	Asbestos Content
Gray Caulk	ND
White Caulk	ND
Sample Composite Homogeneity: Good	

Location: 21B, Exterior White/Grey Window Caulking

Lab ID-Version‡: 13867404-1

Sample Layers	Asbestos Content
Gray Caulk	ND
White Caulk	ND
Sample Composite Homogeneity: Good	

Location: 21C, Exterior White/Grey Window Caulking

Lab ID-Version‡: 13867405-1

Sample Layers	Asbestos Content
Gray Caulk	ND
White Caulk	ND
Sample Composite Homogeneity: Good	

Location: 22A, Grey 2'x2' Rough Ceiling Tile

Lab ID-Version‡: 13867406-1

Sample Layers	Asbestos Content
Silver Tape	ND
Gray Ceiling Tile	ND
White Coating	ND
Composite Non-Asbestos Content:	60% Mineral Wool 5% Cellulose
Sample Composite Homogeneity: Good	

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center West Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022

Date of Receipt: 04-04-2022

Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Location: 22B, Grey 2'x2' Rough Ceiling Tile**

Lab ID-Version‡: 13867407-1

Sample Layers	Asbestos Content
Silver Tape	ND
Gray Ceiling Tile	ND
White Coating	ND
Composite Non-Asbestos Content:	60% Mineral Wool 5% Cellulose
Sample Composite Homogeneity:	Good

Location: 22C, Grey 2'x2' Rough Ceiling Tile

Lab ID-Version‡: 13867408-1

Sample Layers	Asbestos Content
Silver Tape	ND
Gray Ceiling Tile	ND
White Coating	ND
Composite Non-Asbestos Content:	60% Mineral Wool 5% Cellulose
Sample Composite Homogeneity:	Good

Location: 23A, White 2'x4' Worm Ceiling Tile

Lab ID-Version‡: 13867409-1

Sample Layers	Asbestos Content
Gray Ceiling Tile	ND
White Coating	ND
Composite Non-Asbestos Content:	40% Cellulose 10% Mineral Wool
Sample Composite Homogeneity:	Good

Location: 23B, White 2'x4' Worm Ceiling Tile

Lab ID-Version‡: 13867410-1

Sample Layers	Asbestos Content
Gray Ceiling Tile	ND
White Coating	ND
Composite Non-Asbestos Content:	40% Cellulose 10% Mineral Wool
Sample Composite Homogeneity:	Good

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center West Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022

Date of Receipt: 04-04-2022

Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Location: 23C, White 2'x4' Worm Ceiling Tile**

Lab ID-Version‡: 13867411-1

Sample Layers	Asbestos Content
Gray Ceiling Tile	ND
White Coating	ND
Composite Non-Asbestos Content:	40% Cellulose 10% Mineral Wool
Sample Composite Homogeneity:	Good

Location: 23D, White 2'x4' Worm Ceiling Tile

Lab ID-Version‡: 13867412-1

Sample Layers	Asbestos Content
Gray Ceiling Tile	ND
White Coating	ND
Composite Non-Asbestos Content:	40% Cellulose 10% Mineral Wool
Sample Composite Homogeneity:	Good

Location: 23E, White 2'x4' Worm Ceiling Tile

Lab ID-Version‡: 13867413-1

Sample Layers	Asbestos Content
Gray Ceiling Tile	ND
White Coating	ND
Composite Non-Asbestos Content:	40% Cellulose 10% Mineral Wool
Sample Composite Homogeneity:	Good

Location: 24A, Perimeter Drywall and Joint Compound

Lab ID-Version‡: 13867414-1

Sample Layers	Asbestos Content
Off-White Drywall	ND
Brown Paper	ND
White Joint Compound	ND
Cream Tape	ND
Composite Non-Asbestos Content:	15% Cellulose
Sample Composite Homogeneity:	Moderate

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center West Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022

Date of Receipt: 04-04-2022

Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Location: 24B, Perimeter Drywall and Joint Compound**

Lab ID-Version‡: 13867415-1

Sample Layers	Asbestos Content
Off-White Drywall	ND
Brown Paper	ND
White Joint Compound	ND
White Paint	ND
Composite Non-Asbestos Content:	10% Cellulose
Sample Composite Homogeneity:	Moderate

Location: 24C, Perimeter Drywall and Joint Compound

Lab ID-Version‡: 13867416-1

Sample Layers	Asbestos Content
Off-White Drywall	ND
Brown Paper	ND
White Joint Compound	ND
White Paint	ND
Composite Non-Asbestos Content:	10% Cellulose
Sample Composite Homogeneity:	Moderate

Location: 24D, Perimeter Drywall and Joint Compound

Lab ID-Version‡: 13867417-1

Sample Layers	Asbestos Content
White Drywall	ND
Brown Paper	ND
White Joint Compound	ND
White Paint	ND
Composite Non-Asbestos Content:	10% Cellulose
Sample Composite Homogeneity:	Moderate

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center West Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022

Date of Receipt: 04-04-2022

Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Location: 24E, Perimeter Drywall and Joint Compound**

Lab ID-Version‡: 13867418-1

Sample Layers	Asbestos Content
White Drywall	ND
Brown Paper	ND
White Joint Compound	ND
Cream Tape	ND
White Texture	ND
White Paint	ND
Composite Non-Asbestos Content:	15% Cellulose
Sample Composite Homogeneity:	Moderate

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center West Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022

Date of Receipt: 04-04-2022

Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Location: 25A, Interior Drywall and Joint Compound**

Lab ID-Version‡: 13867419-1

Sample Layers	Asbestos Content
Off-White Drywall	ND
Brown Paper	ND
White Joint Compound	ND
White Paint	ND
Composite Non-Asbestos Content:	10% Cellulose
Sample Composite Homogeneity:	Moderate

Location: 25B, Interior Drywall and Joint Compound

Lab ID-Version‡: 13867420-1

Sample Layers	Asbestos Content
White Drywall	ND
Brown Paper	ND
White Joint Compound	ND
White Paint	ND
Composite Non-Asbestos Content:	10% Cellulose
Sample Composite Homogeneity:	Moderate

Location: 25C, Interior Drywall and Joint Compound

Lab ID-Version‡: 13867421-1

Sample Layers	Asbestos Content
Off-White Drywall	ND
Brown Paper	ND
White Joint Compound	ND
White Paint	ND
Composite Non-Asbestos Content:	10% Cellulose
Sample Composite Homogeneity:	Moderate

Location: 25D, Interior Drywall and Joint Compound

Lab ID-Version‡: 13867422-1

Sample Layers	Asbestos Content
White Drywall	ND
Brown Paper	ND
White Joint Compound	ND
White Paint	ND
Composite Non-Asbestos Content:	10% Cellulose
Sample Composite Homogeneity:	Moderate

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center West Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022

Date of Receipt: 04-04-2022

Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Location: 25E, Interior Drywall and Joint Compound**

Lab ID-Version‡: 13867423-1

Sample Layers	Asbestos Content
White Drywall	ND
Brown Paper	ND
White Joint Compound	ND
White Paint	ND
Composite Non-Asbestos Content:	10% Cellulose
Sample Composite Homogeneity:	Moderate

Location: 26A, White 12"x12" Dotted Ceiling Tile

Lab ID-Version‡: 13867424-1

Sample Layers	Asbestos Content
Gray Ceiling Tile	ND
White Coating	ND
Composite Non-Asbestos Content:	35% Cellulose 15% Mineral Wool
Sample Composite Homogeneity:	Good

Location: 26B, White 12"x12" Dotted Ceiling Tile

Lab ID-Version‡: 13867425-1

Sample Layers	Asbestos Content
Gray Ceiling Tile	ND
White Coating	ND
Composite Non-Asbestos Content:	35% Cellulose 15% Mineral Wool
Sample Composite Homogeneity:	Good

Location: 26C, White 12"x12" Dotted Ceiling Tile

Lab ID-Version‡: 13867426-1

Sample Layers	Asbestos Content
Gray Ceiling Tile	ND
White Coating	ND
Composite Non-Asbestos Content:	35% Cellulose 15% Mineral Wool
Sample Composite Homogeneity:	Good

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center West Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022

Date of Receipt: 04-04-2022

Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Location: 27A, Drywall and Joint Compound Ceiling**

Lab ID-Version‡: 13867427-1

Sample Layers	Asbestos Content
White Drywall	ND
Brown Paper	ND
White Joint Compound	ND
White Paint	ND
Composite Non-Asbestos Content:	10% Cellulose
Sample Composite Homogeneity:	Moderate

Location: 27B, Drywall and Joint Compound Ceiling

Lab ID-Version‡: 13867428-1

Sample Layers	Asbestos Content
White Drywall	ND
Brown Paper	ND
White Joint Compound	ND
White Paint	ND
Composite Non-Asbestos Content:	10% Cellulose
Sample Composite Homogeneity:	Moderate

Location: 27C, Drywall and Joint Compound Ceiling

Lab ID-Version‡: 13867429-1

Sample Layers	Asbestos Content
Off-White Drywall	ND
Brown Paper	ND
White Joint Compound	ND
White Paint	ND
Composite Non-Asbestos Content:	10% Cellulose
Sample Composite Homogeneity:	Moderate

Location: 28A, Green 4"x4" Ceramic Wall Tile, Grout and Thin Set

Lab ID-Version‡: 13867430-1

Sample Layers	Asbestos Content
White Thinset	ND
White Grout	ND
Green Ceramic Tile	ND
Sample Composite Homogeneity:	Good

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center West Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022

Date of Receipt: 04-04-2022

Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Location: 28B, Green 4"x4" Ceramic Wall Tile, Grout and Thin Set**

Lab ID-Version‡: 13867431-1

Sample Layers	Asbestos Content
White Thinset	ND
White Grout	ND
Green Ceramic Tile	ND
Sample Composite Homogeneity: Good	

Location: 28C, Green 4"x4" Ceramic Wall Tile, Grout and Thin Set

Lab ID-Version‡: 13867432-1

Sample Layers	Asbestos Content
White Thinset	ND
White Grout	ND
Green Ceramic Tile	ND
Sample Composite Homogeneity: Good	

Location: 29A, Beige 4"x4" Ceramic Wall Tile, Grout and Thin Set

Lab ID-Version‡: 13867433-1

Sample Layers	Asbestos Content
White Thinset	ND
White Grout	ND
Beige Ceramic Tile	ND
Sample Composite Homogeneity: Good	

Location: 29B, Beige 4"x4" Ceramic Wall Tile, Grout and Thin Set

Lab ID-Version‡: 13867434-1

Sample Layers	Asbestos Content
White Thinset	ND
White Grout	ND
Beige Ceramic Tile	ND
Sample Composite Homogeneity: Good	

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by -"x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center West Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022

Date of Receipt: 04-04-2022

Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Location: 29C, Beige 4"x4" Ceramic Wall Tile, Grout and Thin Set**

Lab ID-Version‡: 13867435-1

Sample Layers	Asbestos Content
White Thinset	ND
White Grout	ND
Beige Ceramic Tile	ND
Sample Composite Homogeneity: Good	

Location: 30A, White 4" Baseboard and Brown Glue

Lab ID-Version‡: 13867436-1

Sample Layers	Asbestos Content
Brown Paper	ND
White Paint	ND
Brown Glue	ND
White Baseboard	ND
Composite Non-Asbestos Content:	3% Cellulose
Sample Composite Homogeneity: Good	

Location: 30B, White 4" Baseboard and Brown Glue

Lab ID-Version‡: 13867437-1

Sample Layers	Asbestos Content
White Paint	ND
Brown Glue	ND
White Baseboard	ND
Sample Composite Homogeneity: Good	

Location: 30C, White 4" Baseboard and Brown Glue

Lab ID-Version‡: 13867438-1

Sample Layers	Asbestos Content
Brown Glue	ND
White Baseboard	ND
Sample Composite Homogeneity: Good	

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center West Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022

Date of Receipt: 04-04-2022

Date of Report: 04-07-2022

ASBESTOS PLM REPORT

Location: 31A, Grey 12"x12" Vinyl Floor Tile and Brown Glue over Grey 12"x12" Vinyl Floor Tile and Black Mastic

Lab ID-Version‡: 13867439-1

Sample Layers	Asbestos Content
Black Mastic	10% Chrysotile
Gray Floor Tile 2	ND
Brown Glue	ND
Gray Floor Tile 1	ND
Sample Composite Homogeneity: Moderate	

Location: 31B, Grey 12"x12" Vinyl Floor Tile and Brown Glue over Grey 12"x12" Vinyl Floor Tile and Black Mastic

Lab ID-Version‡: 13867440-1

Sample Layers	Asbestos Content
Black Mastic	10% Chrysotile
Gray Floor Tile 2	ND
Brown Glue	ND
Gray Floor Tile 1	ND
Sample Composite Homogeneity: Moderate	

Location: 31C, Grey 12"x12" Vinyl Floor Tile and Brown Glue over Grey 12"x12" Vinyl Floor Tile and Black Mastic

Lab ID-Version‡: 13867441-1

Sample Layers	Asbestos Content
Black Mastic	10% Chrysotile
Gray Floor Tile 2	ND
Brown Glue	ND
Gray Floor Tile 1	ND
Sample Composite Homogeneity: Moderate	

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center West Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022
 Date of Receipt: 04-04-2022
 Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Location: 32A, Green Carpet and Brown Glue**

Lab ID-Version‡: 13867442-1

Sample Layers	Asbestos Content
Brown Glue	ND
Green Carpet	ND
Composite Non-Asbestos Content:	60% Synthetic Fibers 5% Polyethylene 3% Nylon
Sample Composite Homogeneity:	Good

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center West Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022

Date of Receipt: 04-04-2022

Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Location: 32B, Green Carpet and Brown Glue**

Lab ID-Version‡: 13867443-1

Sample Layers	Asbestos Content
Brown Glue	ND
Green Carpet	ND
Composite Non-Asbestos Content:	60% Synthetic Fibers 5% Polyethylene 3% Nylon
Sample Composite Homogeneity:	Good

Location: 32C, Green Carpet and Brown Glue

Lab ID-Version‡: 13867444-1

Sample Layers	Asbestos Content
Brown Glue	ND
Green Carpet	ND
Composite Non-Asbestos Content:	60% Synthetic Fibers 5% Polyethylene 3% Nylon
Sample Composite Homogeneity:	Good

Location: 32D, Green Carpet and Brown Glue

Lab ID-Version‡: 13867445-1

Sample Layers	Asbestos Content
Brown Glue	ND
Green Carpet	ND
Composite Non-Asbestos Content:	60% Synthetic Fibers 5% Polyethylene 3% Nylon
Sample Composite Homogeneity:	Good

Location: 32E, Green Carpet and Brown Glue

Lab ID-Version‡: 13867446-1

Sample Layers	Asbestos Content
Brown Glue	ND
Green Carpet	ND
Composite Non-Asbestos Content:	60% Synthetic Fibers 5% Polyethylene 3% Nylon
Sample Composite Homogeneity:	Good

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center West Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022

Date of Receipt: 04-04-2022

Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Location: 33A, Pink Carpet and Brown Glue**

Lab ID-Version‡: 13867447-1

Sample Layers	Asbestos Content
Brown Glue	ND
Pink Carpet	ND
Composite Non-Asbestos Content:	60% Synthetic Fibers 5% Polyethylene 3% Nylon
Sample Composite Homogeneity:	Good

Location: 33B, Pink Carpet and Brown Glue

Lab ID-Version‡: 13867448-1

Sample Layers	Asbestos Content
Brown Glue	ND
Pink Carpet	ND
Composite Non-Asbestos Content:	60% Synthetic Fibers 5% Polyethylene 3% Nylon
Sample Composite Homogeneity:	Good

Location: 33C, Pink Carpet and Brown Glue

Lab ID-Version‡: 13867449-1

Sample Layers	Asbestos Content
Brown Glue	ND
Pink Carpet	ND
Composite Non-Asbestos Content:	60% Synthetic Fibers 5% Polyethylene 3% Nylon
Sample Composite Homogeneity:	Good

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center West Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022
 Date of Receipt: 04-04-2022
 Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Location: 34A, Perimeter Plaster and Drywall**

Lab ID-Version‡: 13867450-1

Sample Layers	Asbestos Content
Off-White Drywall	ND
Brown Paper	ND
White Joint Compound	ND
White Paint 2	ND
Gray Plaster	ND
White Plaster	ND
White Paint 1	ND
Composite Non-Asbestos Content:	5% Cellulose
Sample Composite Homogeneity:	Moderate

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center West Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022

Date of Receipt: 04-04-2022

Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Location: 34B, Perimeter Plaster and Drywall**

Lab ID-Version‡: 13867451-1

Sample Layers	Asbestos Content
Off-White Drywall	ND
Brown Paper	ND
White Joint Compound	ND
White Paint 2	ND
Gray Plaster	ND
White Plaster	ND
White Paint 1	ND
Composite Non-Asbestos Content:	5% Cellulose
Sample Composite Homogeneity:	Moderate

Location: 34C, Perimeter Plaster and Drywall

Lab ID-Version‡: 13867452-1

Sample Layers	Asbestos Content
Off-White Drywall	ND
Brown Paper	ND
White Joint Compound	ND
White Paint 2	ND
Gray Plaster	ND
White Plaster	ND
White Paint 1	ND
Composite Non-Asbestos Content:	5% Cellulose
Sample Composite Homogeneity:	Moderate

Location: 35A, Grey 12"x12" Vinyl Floor Tile and Brown Glue over Brown 12"x12" Vinyl Floor Tile and Black Mastic

Lab ID-Version‡: 13867453-1

Sample Layers	Asbestos Content
Black Mastic	5% Chrysotile
Brown Floor Tile	ND
Brown Glue	ND
Gray Floor Tile	ND
Sample Composite Homogeneity:	Moderate

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by -"x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
C/O: Mr. Sergio Adasme
Re: Aquatic Center West Building; 501 Seabreeze
Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022
Date of Receipt: 04-04-2022
Date of Report: 04-07-2022

ASBESTOS PLM REPORT

Location: 35B, Grey 12"x12" Vinyl Floor Tile and Brown Glue over Brown 12"x12" Vinyl Floor Tile and Black Mastic

Lab ID-Version‡: 13867454-1

Sample Layers	Asbestos Content
Black Mastic	5% Chrysotile
Brown Floor Tile	ND
Brown Glue	ND
Gray Floor Tile	ND
Sample Composite Homogeneity:	Moderate

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center West Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022

Date of Receipt: 04-04-2022

Date of Report: 04-07-2022

ASBESTOS PLM REPORT

Location: 35C, Grey 12"x12" Vinyl Floor Tile and Brown Glue over Brown 12"x12" Vinyl Floor Tile and Black Mastic

Lab ID-Version‡: 13867455-1

Sample Layers	Asbestos Content
Black Mastic	5% Chrysotile
Brown Floor Tile	ND
Brown Glue	ND
Gray Floor Tile	ND
Sample Composite Homogeneity: Moderate	

Location: 36A, Brown Wood Pattern 4"x36" Vinyl Floor Plank

Lab ID-Version‡: 13867456-1

Sample Layers	Asbestos Content
Brown Sheet Flooring	ND
Sample Composite Homogeneity: Good	

Location: 36B, Brown Wood Pattern 4"x36" Vinyl Floor Plank

Lab ID-Version‡: 13867457-1

Sample Layers	Asbestos Content
Brown Sheet Flooring	ND
Sample Composite Homogeneity: Good	

Location: 36C, Brown Wood Pattern 4"x36" Vinyl Floor Plank

Lab ID-Version‡: 13867458-1

Sample Layers	Asbestos Content
Brown Sheet Flooring	ND
Sample Composite Homogeneity: Good	

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center West Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022

Date of Receipt: 04-04-2022

Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Location: 37A, Brown 12"x12" Ceramic Floor Tile, Grout, Thin Set and Black Mastic**

Lab ID-Version‡: 13867459-1

Sample Layers	Asbestos Content
Black Mastic	5% Chrysotile
Gray Thinset	ND
Gray Grout	ND
Brown Ceramic Tile	ND
Sample Composite Homogeneity: Moderate	

Location: 37B, Brown 12"x12" Ceramic Floor Tile, Grout, Thin Set and Black Mastic

Lab ID-Version‡: 13867460-1

Sample Layers	Asbestos Content
Black Mastic	5% Chrysotile
Gray Thinset	ND
Gray Grout	ND
Brown Ceramic Tile	ND
Sample Composite Homogeneity: Moderate	

Location: 37C, Brown 12"x12" Ceramic Floor Tile, Grout, Thin Set and Black Mastic

Lab ID-Version‡: 13867461-1

Sample Layers	Asbestos Content
Black Mastic	5% Chrysotile
Gray Thinset	ND
Gray Grout	ND
Brown Ceramic Tile	ND
Sample Composite Homogeneity: Moderate	

Location: 38A, White Fiber Glass Reinforced Panel and Brown Glue

Lab ID-Version‡: 13867462-1

Sample Layers	Asbestos Content
Brown Glue	ND
White Fiberglass Reinforced Plastic	ND
Composite Non-Asbestos Content: 30% Glass Fibers	
Sample Composite Homogeneity: Good	

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center West Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022

Date of Receipt: 04-04-2022

Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Location: 38B, White Fiber Glass Reinforced Panel and Brown Glue**

Lab ID-Version‡: 13867463-1

Sample Layers	Asbestos Content
Brown Glue	ND
White Fiberglass Reinforced Plastic	ND
Composite Non-Asbestos Content:	30% Glass Fibers
Sample Composite Homogeneity:	Good

Location: 38C, White Fiber Glass Reinforced Panel and Brown Glue

Lab ID-Version‡: 13867464-1

Sample Layers	Asbestos Content
Brown Glue	ND
White Fiberglass Reinforced Plastic	ND
Composite Non-Asbestos Content:	30% Glass Fibers
Sample Composite Homogeneity:	Good

Location: 39A, Black Mastic on HVAC Ducts

Lab ID-Version‡: 13867465-1

Sample Layers	Asbestos Content
Black Mastic	5% Chrysotile
Composite Non-Asbestos Content:	5% Glass Fibers
Sample Composite Homogeneity:	Good

Location: 39B, Black Mastic on HVAC Ducts

Lab ID-Version‡: 13867466-1

Sample Layers	Asbestos Content
Brown Glue	ND
Brown Paper	ND
Silver Foil	ND
Black Mastic	5% Chrysotile
Composite Non-Asbestos Content:	5% Cellulose 5% Glass Fibers
Sample Composite Homogeneity:	Moderate

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center West Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022

Date of Receipt: 04-04-2022

Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Location: 39C, Black Mastic on HVAC Ducts**

Lab ID-Version‡: 13867467-1

Sample Layers	Asbestos Content
Brown Glue	ND
Brown Paper	ND
Silver Foil	ND
Black Mastic	5% Chrysotile
Composite Non-Asbestos Content:	5% Cellulose 5% Glass Fibers
Sample Composite Homogeneity:	Moderate

Location: 39D, Black Mastic on HVAC Ducts

Lab ID-Version‡: 13867468-1

Sample Layers	Asbestos Content
White Insulation	ND
Brown Paper	ND
Silver Foil	ND
Black Mastic	5% Chrysotile
Composite Non-Asbestos Content:	5% Cellulose 3% Glass Fibers 3% Mineral Wool
Sample Composite Homogeneity:	Moderate

Location: 39E, Black Mastic on HVAC Ducts

Lab ID-Version‡: 13867469-1

Sample Layers	Asbestos Content
Brown Glue	ND
Brown Paper	ND
Silver Foil	ND
Black Mastic	5% Chrysotile
Composite Non-Asbestos Content:	5% Cellulose 5% Glass Fibers
Sample Composite Homogeneity:	Moderate

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
C/O: Mr. Sergio Adasme
Re: Aquatic Center West Building; 501 Seabreeze
Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022

Date of Receipt: 04-04-2022

Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Location: 40A, Brown/ White 1'x1' Ceramic Floor Tile, Grout and Thin Set**

Lab ID-Version‡: 13867470-1

Sample Layers	Asbestos Content
Gray Thinset	ND
White Grout	ND
Brown/White Ceramic Tile	ND
Sample Composite Homogeneity: Good	

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by -"x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center West Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022

Date of Receipt: 04-04-2022

Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Location: 40B, Brown/ White 1'x1' Ceramic Floor Tile, Grout and Thin Set**

Lab ID-Version‡: 13867471-1

Sample Layers	Asbestos Content
Gray Thinset	ND
White Grout	ND
Brown/White Ceramic Tile	ND
Sample Composite Homogeneity: Good	

Location: 40C, Brown/ White 1'x1' Ceramic Floor Tile, Grout and Thin Set

Lab ID-Version‡: 13867472-1

Sample Layers	Asbestos Content
Gray Thinset	ND
White Grout	ND
Brown/White Ceramic Tile	ND
Sample Composite Homogeneity: Good	

Location: 41A, Grey Sink Undercoating

Lab ID-Version‡: 13867473-1

Sample Layers	Asbestos Content
Gray Mastic	ND
Sample Composite Homogeneity: Good	

Location: 41B, Grey Sink Undercoating

Lab ID-Version‡: 13867474-1

Sample Layers	Asbestos Content
Gray Mastic	ND
Sample Composite Homogeneity: Good	

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by -"x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center West Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022
 Date of Receipt: 04-04-2022
 Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Location: 41C, Grey Sink Undercoating**

Lab ID-Version‡: 13867475-1

Sample Layers	Asbestos Content
Gray Mastic	ND
Sample Composite Homogeneity: Good	

Location: 42A, Grey 4"x4" Ceramic Wall/Floor Tile, Grout and Thin Set

Lab ID-Version‡: 13867476-1

Sample Layers	Asbestos Content
Yellow Mastic	ND
Gray Thinset	ND
Gray Grout	ND
Gray Ceramic Tile	ND
Sample Composite Homogeneity: Good	

Location: 42B, Grey 4"x4" Ceramic Wall/Floor Tile, Grout and Thin Set

Lab ID-Version‡: 13867477-1

Sample Layers	Asbestos Content
Yellow Mastic	ND
Gray Thinset	ND
Gray Grout	ND
Gray Ceramic Tile	ND
Sample Composite Homogeneity: Good	

Location: 42C, Grey 4"x4" Ceramic Wall/Floor Tile, Grout and Thin Set

Lab ID-Version‡: 13867478-1

Sample Layers	Asbestos Content
Brown Paper	ND
Yellow Mastic	ND
Gray Thinset	ND
Gray Grout	ND
Gray Ceramic Tile	ND
Composite Non-Asbestos Content: 3% Cellulose	
Sample Composite Homogeneity: Good	

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by -"x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center West Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022

Date of Receipt: 04-04-2022

Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Location: 43A, Pink 4"x4" Ceramic Wall/Floor Tile, Grout and Thin Set**

Lab ID-Version‡: 13867479-1

Sample Layers	Asbestos Content
Yellow Mastic	ND
Gray Thinset	ND
Gray Grout	ND
Pink Ceramic Tile	ND
Sample Composite Homogeneity: Good	

Location: 43B, Pink 4"x4" Ceramic Wall/Floor Tile, Grout and Thin Set

Lab ID-Version‡: 13867480-1

Sample Layers	Asbestos Content
Yellow Mastic	ND
Gray Thinset	ND
Gray Grout	ND
Pink Ceramic Tile	ND
Sample Composite Homogeneity: Good	

Location: 43C, Pink 4"x4" Ceramic Wall/Floor Tile, Grout and Thin Set

Lab ID-Version‡: 13867481-1

Sample Layers	Asbestos Content
Yellow Mastic	ND
Gray Thinset	ND
Gray Grout	ND
Pink Ceramic Tile	ND
Sample Composite Homogeneity: Good	

Location: 44A, Interior Stucco Ceiling

Lab ID-Version‡: 13867482-1

Sample Layers	Asbestos Content
Gray Plaster	ND
White Plaster	ND
White Paint	ND
Sample Composite Homogeneity: Good	

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center West Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022

Date of Receipt: 04-04-2022

Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Location: 44B, Interior Stucco Ceiling**

Lab ID-Version‡: 13867483-1

Sample Layers	Asbestos Content
Gray Plaster	ND
White Plaster	ND
White Paint	ND
Sample Composite Homogeneity: Good	

Location: 44C, Interior Stucco Ceiling

Lab ID-Version‡: 13867484-1

Sample Layers	Asbestos Content
Gray Plaster	ND
White Plaster	ND
White Paint	ND
Sample Composite Homogeneity: Good	

Location: 45A, Brown Wood Pattern 6"x48" Ceramic Floor Tile, Grout, Thin Set and Brown Glue

Lab ID-Version‡: 13867485-1

Sample Layers	Asbestos Content
Yellow Mastic	ND
White Thinset	ND
Gray Grout	ND
Brown Ceramic Tile	ND
Sample Composite Homogeneity: Good	

Location: 45B, Brown Wood Pattern 6"x48" Ceramic Floor Tile, Grout, Thin Set and Brown Glue

Lab ID-Version‡: 13867486-1

Sample Layers	Asbestos Content
Yellow Mastic	ND
White Thinset	ND
Gray Grout	ND
Brown Ceramic Tile	ND
Sample Composite Homogeneity: Good	

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center West Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022

Date of Receipt: 04-04-2022

Date of Report: 04-07-2022

ASBESTOS PLM REPORT

Location: 45C, Brown Wood Pattern 6"x48" Ceramic Floor Tile, Grout, Thin Set and Brown Glue

Lab ID-Version‡: 13867487-1

Sample Layers	Asbestos Content
Yellow Mastic	ND
White Thinset	ND
Gray Grout	ND
Brown Ceramic Tile	ND
Sample Composite Homogeneity: Good	

Location: 46A, White 12"x12" Holes Ceiling Tile and Brown Glue

Lab ID-Version‡: 13867488-1

Sample Layers	Asbestos Content
Brown Glue	ND
Brown Ceiling Tile	ND
White Coating	ND
Composite Non-Asbestos Content:	60% Cellulose 1% Wollastonite
Sample Composite Homogeneity: Moderate	

Location: 46B, White 12"x12" Holes Ceiling Tile and Brown Glue

Lab ID-Version‡: 13867489-1

Sample Layers	Asbestos Content
Brown Glue	ND
Brown Ceiling Tile	ND
White Coating	ND
Composite Non-Asbestos Content:	60% Cellulose 1% Wollastonite
Sample Composite Homogeneity: Moderate	

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center West Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022
 Date of Receipt: 04-04-2022
 Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Location: 46C, White 12"x12" Holes Ceiling Tile and Brown Glue**

Lab ID-Version‡: 13867490-1

Sample Layers	Asbestos Content
Brown Glue	ND
Brown Ceiling Tile	ND
White Coating	ND
Composite Non-Asbestos Content:	60% Cellulose 1% Wollastonite
Sample Composite Homogeneity:	Moderate

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center West Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022

Date of Receipt: 04-04-2022

Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Location: 47A, Stone and Mortar Staircase**

Lab ID-Version‡: 13867491-1

Sample Layers	Asbestos Content
Gray Mortar	ND
Gray Non-Fibrous Material (Stone)	ND
Sample Composite Homogeneity: Good	

Location: 47B, Stone and Mortar Staircase

Lab ID-Version‡: 13867492-1

Sample Layers	Asbestos Content
Gray Mortar	ND
Gray Non-Fibrous Material (Stone)	ND
Sample Composite Homogeneity: Good	

Location: 47C, Stone and Mortar Staircase

Lab ID-Version‡: 13867493-1

Sample Layers	Asbestos Content
Gray Mortar	ND
Gray Non-Fibrous Material (Stone)	ND
Sample Composite Homogeneity: Good	

Location: 48A, Black Mirror Mastic

Lab ID-Version‡: 13867494-1

Sample Layers	Asbestos Content
Black Mastic	10% Chrysotile
Sample Composite Homogeneity: Good	

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center West Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022

Date of Receipt: 04-04-2022

Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Location: 48B, Black Mirror Mastic**

Lab ID-Version‡: 13867495-1

Sample Layers	Asbestos Content
Black Mastic	10% Chrysotile
Sample Composite Homogeneity: Good	

Location: 48C, Black Mirror Mastic

Lab ID-Version‡: 13867496-1

Sample Layers	Asbestos Content
Black Mastic	10% Chrysotile
Sample Composite Homogeneity: Good	

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Report for:

Mr. Sergio Adasme
Terracon - Fort Lauderdale, FL
5371 NW 33rd Ave.
Suite 201
Fort Lauderdale, FL 33309

Regarding: Project: Aquatic Center East Building; 501 Seabreeze Blvd. Fort Lauderdale, FL
EML ID: 2890785

Approved by:



Approved Signatory
Balu Krishnan

Dates of Analysis:

Asbestos PLM: 04-06-2022 and 04-07-2022

Service SOPs: Asbestos PLM (EPA 40CFR App E to Sub E of Part 763 & EPA METHOD 600/R-93-116, SOP EM-AS-S-1267)
NVLAP Lab Code 201060-0

All samples were received in acceptable condition unless noted in the Report Comments portion in the body of the report. The results relate only to the samples as received and tested. The results include an inherent uncertainty of measurement associated with estimating percentages by polarized light microscopy. Measurement uncertainty data for sample results with >1% asbestos concentration can be provided when requested.

Eurofins EMLab P&K ("the Company") shall have no liability to the client or the client's customer with respect to decisions or recommendations made, actions taken or courses of conduct implemented by either the client or the client's customer as a result of or based upon the Test Results. In no event shall the Company be liable to the client with respect to the Test Results except for the Company's own willful misconduct or gross negligence nor shall the Company be liable for incidental or consequential damages or lost profits or revenues to the fullest extent such liability may be disclaimed by law, even if the Company has been advised of the possibility of such damages, lost profits or lost revenues. In no event shall the Company's liability with respect to the Test Results exceed the amount paid to the Company by the client therefor.

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center East Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Eurofins EMLab P&K
 6215 Regency Parkway, Suite 900, Norcross, GA 30071
 (866) 871-1984 Fax (954) 776-8485 www.emlab.com
 Date of Sampling: 04-04-2022
 Date of Receipt: 04-04-2022
 Date of Report: 04-07-2022

ASBESTOS PLM REPORT

Total Samples Submitted: 73

Total Samples Analyzed: 73

Total Samples with Layer Asbestos Content > 1%: 0

Location: 1001A, Exterior Stucco

Lab ID-Version‡: 13867675-1

Sample Layers	Asbestos Content
White Paint	ND
Gray Stucco	ND
Composite Non-Asbestos Content:	< 1% Glass Fibers
Sample Composite Homogeneity:	Moderate

Location: 1001B, Exterior Stucco

Lab ID-Version‡: 13867676-1

Sample Layers	Asbestos Content
Red Paint	ND
Gray Stucco	ND
Composite Non-Asbestos Content:	< 1% Glass Fibers
Sample Composite Homogeneity:	Moderate

Location: 1001C, Exterior Stucco

Lab ID-Version‡: 13867677-1

Sample Layers	Asbestos Content
White Paint	ND
Gray Stucco	ND
Composite Non-Asbestos Content:	< 1% Glass Fibers
Sample Composite Homogeneity:	Moderate

Location: 1002A, Exterior Green Ceramic Wall Tile, Grout and Thin Set

Lab ID-Version‡: 13867678-1

Sample Layers	Asbestos Content
Green Ceramic Tile	ND
Light Gray Grout	ND
Gray Thinset	ND
Sample Composite Homogeneity:	Moderate

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
C/O: Mr. Sergio Adasme
Re: Aquatic Center East Building; 501 Seabreeze
Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022
Date of Receipt: 04-04-2022
Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Location: 1002B, Exterior Green Ceramic Wall Tile, Grout and Thin Set**

Lab ID-Version‡: 13867679-1

Sample Layers	Asbestos Content
Green Ceramic Tile	ND
Light Gray Grout	ND
Gray Thinset	ND
Sample Composite Homogeneity: Moderate	

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center East Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022

Date of Receipt: 04-04-2022

Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Location: 1002C, Exterior Green Ceramic Wall Tile, Grout and Thin Set**

Lab ID-Version‡: 13867680-1

Sample Layers	Asbestos Content
Green Ceramic Tile	ND
Light Gray Grout	ND
Gray Thinset	ND
Sample Composite Homogeneity: Moderate	

Location: 1003A, Exterior Multicolor 1"x1" Ceramic Wall and Tile, Grout and Thin Set

Lab ID-Version‡: 13867681-1

Sample Layers	Asbestos Content
Yellow Ceramic Tile	ND
Blue Ceramic Tile	ND
Green Ceramic Tile	ND
Red Ceramic Tile	ND
Black Ceramic Tile	ND
Light Gray Grout	ND
Gray Thinset	ND
Sample Composite Homogeneity: Moderate	

Location: 1003B, Exterior Multicolor 1"x1" Ceramic Wall and Tile, Grout and Thin Set

Lab ID-Version‡: 13867682-1

Sample Layers	Asbestos Content
Yellow Ceramic Tile	ND
Blue Ceramic Tile	ND
Green Ceramic Tile	ND
Red Ceramic Tile	ND
Black Ceramic Tile	ND
Light Gray Grout	ND
Gray Thinset	ND
Sample Composite Homogeneity: Moderate	

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center East Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022
 Date of Receipt: 04-04-2022
 Date of Report: 04-07-2022

ASBESTOS PLM REPORT

Location: 1003C, Exterior Multicolor 1"x1" Ceramic Wall and Tile, Grout and Thin Set Lab ID-Version‡: 13867683-1

Sample Layers	Asbestos Content
Yellow Ceramic Tile	ND
Blue Ceramic Tile	ND
Green Ceramic Tile	ND
Red Ceramic Tile	ND
Black Ceramic Tile	ND
Light Gray Grout	ND
Gray Thinset	ND
Sample Composite Homogeneity:	Moderate

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center East Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022

Date of Receipt: 04-04-2022

Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Location: 1004A, Exterior Concrete Walkway**

Lab ID-Version‡: 13867684-1

Sample Layers	Asbestos Content
Gray Concrete	ND
Composite Non-Asbestos Content:	< 1% Cellulose
Sample Composite Homogeneity:	Moderate

Location: 1004B, Exterior Concrete Walkway

Lab ID-Version‡: 13867685-1

Sample Layers	Asbestos Content
Gray Concrete	ND
Composite Non-Asbestos Content:	< 1% Cellulose
Sample Composite Homogeneity:	Moderate

Location: 1004C, Exterior Concrete Walkway

Lab ID-Version‡: 13867686-1

Sample Layers	Asbestos Content
Gray Concrete	ND
Composite Non-Asbestos Content:	< 1% Cellulose
Sample Composite Homogeneity:	Moderate

Location: 1005A, Exterior Grey Concrete Walkway Joint Caulking

Lab ID-Version‡: 13867687-1

Sample Layers	Asbestos Content
Gray Caulk	ND
Black Caulk	ND
Sample Composite Homogeneity:	Good

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center East Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022

Date of Receipt: 04-04-2022

Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Location: 1005B, Exterior Grey Concrete Walkway Joint Caulking**

Lab ID-Version‡: 13867688-1

Sample Layers	Asbestos Content
Gray Caulk	ND
Black Caulk	ND
Sample Composite Homogeneity: Good	

Location: 1005C, Exterior Grey Concrete Walkway Joint Caulking

Lab ID-Version‡: 13867689-1

Sample Layers	Asbestos Content
Tan Caulk	ND
Sample Composite Homogeneity: Good	

Location: 1006A, Interior Drywall and Joint Compound

Lab ID-Version‡: 13867690-1

Sample Layers	Asbestos Content
White Joint Compound	ND
White Drywall	ND
Brown Paper	ND
Multicolored Paint	ND
Composite Non-Asbestos Content:	10% Cellulose 2% Glass Fibers
Sample Composite Homogeneity: Moderate	

Location: 1006B, Interior Drywall and Joint Compound

Lab ID-Version‡: 13867691-1

Sample Layers	Asbestos Content
White Joint Compound	ND
White Drywall	ND
Brown Paper	ND
Composite Non-Asbestos Content:	10% Cellulose 2% Glass Fibers
Sample Composite Homogeneity: Moderate	

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center East Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022

Date of Receipt: 04-04-2022

Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Location: 1006C, Interior Drywall and Joint Compound**

Lab ID-Version‡: 13867692-1

Sample Layers	Asbestos Content
White Joint Compound	ND
White Drywall	ND
Brown Paper	ND
White Paint	ND
Composite Non-Asbestos Content:	10% Cellulose 2% Glass Fibers
Sample Composite Homogeneity:	Moderate

Location: 1007A, Perimeter Drywall and Joint Compound

Lab ID-Version‡: 13867693-1

Sample Layers	Asbestos Content
Blue-Green Paint	ND
White Joint Compound	ND
Brown Paper	ND
Off-White Drywall	ND
Composite Non-Asbestos Content:	10% Cellulose
Sample Composite Homogeneity:	Moderate

Location: 1007B, Perimeter Drywall and Joint Compound

Lab ID-Version‡: 13867694-1

Sample Layers	Asbestos Content
Blue-Green Paint	ND
White Texture	ND
Cream Tape	ND
White Joint Compound	ND
Brown Paper	ND
Off-White Drywall	ND
Composite Non-Asbestos Content:	15% Cellulose
Sample Composite Homogeneity:	Moderate

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center East Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022
 Date of Receipt: 04-04-2022
 Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Location: 1007C, Perimeter Drywall and Joint Compound**

Lab ID-Version‡: 13867695-1

Sample Layers	Asbestos Content
White Paint	ND
White Joint Compound	ND
Brown Paper	ND
Off-White Drywall	ND
Composite Non-Asbestos Content:	10% Cellulose
Sample Composite Homogeneity:	Moderate

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center East Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Eurofins EMLab P&K
 6215 Regency Parkway, Suite 900, Norcross, GA 30071
 (866) 871-1984 Fax (954) 776-8485 www.emlab.com
 Date of Sampling: 04-04-2022
 Date of Receipt: 04-04-2022
 Date of Report: 04-07-2022

ASBESTOS PLM REPORT

Location: 1007D, Perimeter Drywall and Joint Compound

Lab ID-Version‡: 13867696-1

Sample Layers	Asbestos Content
White Paint	ND
White Joint Compound	ND
Brown Paper	ND
Off-White Drywall	ND
Composite Non-Asbestos Content:	10% Cellulose
Sample Composite Homogeneity:	Moderate

Location: 1007E, Perimeter Drywall and Joint Compound

Lab ID-Version‡: 13867697-1

Sample Layers	Asbestos Content
White Paint	ND
White Joint Compound	ND
Brown Paper	ND
Off-White Drywall	ND
Composite Non-Asbestos Content:	10% Cellulose 2% Glass Fibers
Sample Composite Homogeneity:	Moderate

Location: 1008A, Brown 3"x36" Wood Pattern Vinyl Floor Tile and Clear Glue

Lab ID-Version‡: 13867698-1

Sample Layers	Asbestos Content
Gray/Black Floor Tile	ND
Gray Floor Tile	ND
Transparent Mastic	ND
Composite Non-Asbestos Content:	< 1% Cellulose
Sample Composite Homogeneity:	Moderate

Location: 1008B, Brown 3"x36" Wood Pattern Vinyl Floor Tile and Clear Glue

Lab ID-Version‡: 13867699-1

Sample Layers	Asbestos Content
Gray/Black Floor Tile	ND
Gray Floor Tile	ND
Transparent Mastic	ND
Composite Non-Asbestos Content:	< 1% Cellulose
Sample Composite Homogeneity:	Moderate

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center East Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022

Date of Receipt: 04-04-2022

Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Location: 1008C, Brown 3"x36" Wood Pattern Vinyl Floor Tile and Clear Glue**

Lab ID-Version‡: 13867700-1

Sample Layers	Asbestos Content
Gray/Black Floor Tile	ND
Transparent Mastic	ND
Composite Non-Asbestos Content:	< 1% Cellulose
Sample Composite Homogeneity:	Moderate

Location: 1009A, Blue 4'x6' Rubber Flooring and Brown Glue

Lab ID-Version‡: 13867701-1

Sample Layers	Asbestos Content
Blue Flooring	ND
Brown Mastic	ND
Composite Non-Asbestos Content:	< 1% Cellulose
Sample Composite Homogeneity:	Moderate

Location: 1009B, Blue 4'x6' Rubber Flooring and Brown Glue

Lab ID-Version‡: 13867702-1

Sample Layers	Asbestos Content
Blue Flooring	ND
Brown Mastic	ND
Composite Non-Asbestos Content:	< 1% Cellulose
Sample Composite Homogeneity:	Moderate

Location: 1009C, Blue 4'x6' Rubber Flooring and Brown Glue

Lab ID-Version‡: 13867703-1

Sample Layers	Asbestos Content
Blue Flooring	ND
Off-White Mastic	ND
Composite Non-Asbestos Content:	< 1% Cellulose
Sample Composite Homogeneity:	Moderate

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center East Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022

Date of Receipt: 04-04-2022

Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Location: 1010A, Drywall and Joint Compound Ceiling**

Lab ID-Version‡: 13867704-1

Sample Layers	Asbestos Content
White Paint	ND
White Joint Compound	ND
Brown Paper	ND
Off-White Drywall	ND
Composite Non-Asbestos Content:	10% Cellulose 2% Glass Fibers
Sample Composite Homogeneity:	Moderate

Location: 1010B, Drywall and Joint Compound Ceiling

Lab ID-Version‡: 13867705-1

Sample Layers	Asbestos Content
White Paint	ND
White Joint Compound	ND
Brown Paper	ND
Off-White Drywall	ND
Composite Non-Asbestos Content:	10% Cellulose 2% Glass Fibers
Sample Composite Homogeneity:	Moderate

Location: 1010C, Drywall and Joint Compound Ceiling

Lab ID-Version‡: 13867706-1

Sample Layers	Asbestos Content
White Paint	ND
White Joint Compound	ND
Brown Paper	ND
Off-White Drywall	ND
Composite Non-Asbestos Content:	10% Cellulose 2% Glass Fibers
Sample Composite Homogeneity:	Moderate

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center East Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022

Date of Receipt: 04-04-2022

Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Location: 1010D, Drywall and Joint Compound Ceiling**

Lab ID-Version‡: 13867707-1

Sample Layers	Asbestos Content
White Paint	ND
White Joint Compound	ND
Brown Paper	ND
Off-White Drywall	ND
Composite Non-Asbestos Content:	10% Cellulose 2% Glass Fibers
Sample Composite Homogeneity:	Moderate

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center East Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022

Date of Receipt: 04-04-2022

Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Location: 1010E, Drywall and Joint Compound Ceiling**

Lab ID-Version‡: 13867708-1

Sample Layers	Asbestos Content
White Paint	ND
White Joint Compound	ND
Brown Paper	ND
Off-White Drywall	ND
Composite Non-Asbestos Content:	10% Cellulose 2% Glass Fibers
Sample Composite Homogeneity:	Moderate

Location: 1011A, White 2'x2' Worm Ceiling Tile

Lab ID-Version‡: 13867709-1

Sample Layers	Asbestos Content
White Coating	ND
Gray Ceiling Tile	ND
Composite Non-Asbestos Content:	20% Cellulose 20% Mineral Wool
Sample Composite Homogeneity:	Good

Location: 1011B, White 2'x2' Worm Ceiling Tile

Lab ID-Version‡: 13867710-1

Sample Layers	Asbestos Content
White Coating	ND
Gray Ceiling Tile	ND
Composite Non-Asbestos Content:	20% Cellulose 20% Mineral Wool
Sample Composite Homogeneity:	Good

Location: 1011C, White 2'x2' Worm Ceiling Tile

Lab ID-Version‡: 13867711-1

Sample Layers	Asbestos Content
White Coating	ND
Gray Ceiling Tile	ND
Composite Non-Asbestos Content:	20% Cellulose 20% Mineral Wool
Sample Composite Homogeneity:	Good

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center East Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022

Date of Receipt: 04-04-2022

Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Location: 1012A, White 6"x6" Ceramic Wall Tile, Grout and Thin Set**

Lab ID-Version‡: 13867712-1

Sample Layers	Asbestos Content
White Ceramic Tile	ND
White Grout	ND
Gray Thinset	ND
Sample Composite Homogeneity: Moderate	

Location: 1012B, White 6"x6" Ceramic Wall Tile, Grout and Thin Set

Lab ID-Version‡: 13867713-1

Sample Layers	Asbestos Content
White Ceramic Tile	ND
White Grout	ND
Gray Thinset	ND
Sample Composite Homogeneity: Moderate	

Location: 1012C, White 6"x6" Ceramic Wall Tile, Grout and Thin Set

Lab ID-Version‡: 13867714-1

Sample Layers	Asbestos Content
White Ceramic Tile	ND
White Grout	ND
Gray Thinset	ND
Sample Composite Homogeneity: Moderate	

Location: 1013A, Grey/Blue Carpet and Brown Glue

Lab ID-Version‡: 13867715-1

Sample Layers	Asbestos Content
Blue Carpet	ND
Brown Mastic	ND
Composite Non-Asbestos Content:	90% Synthetic Fibers < 1% Cellulose
Sample Composite Homogeneity: Moderate	

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center East Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022

Date of Receipt: 04-04-2022

Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Location: 1013B, Grey/Blue Carpet and Brown Glue**

Lab ID-Version‡: 13867716-1

Sample Layers	Asbestos Content
Blue Carpet	ND
Brown Mastic	ND
Composite Non-Asbestos Content:	90% Synthetic Fibers < 1% Cellulose
Sample Composite Homogeneity:	Moderate

Location: 1013C, Grey/Blue Carpet and Brown Glue

Lab ID-Version‡: 13867717-1

Sample Layers	Asbestos Content
Blue Carpet	ND
Brown Mastic	ND
Composite Non-Asbestos Content:	90% Synthetic Fibers < 1% Cellulose
Sample Composite Homogeneity:	Moderate

Location: 1014A, Black/White 16"x16" Ceramic Floor Tile, Grout and Thin Set

Lab ID-Version‡: 13867718-1

Sample Layers	Asbestos Content
Gray Ceramic Tile with Blue Paint	ND
White Ceramic Tile	ND
Gray Thinset	ND
Brown Paper	ND
Off-White Grout	ND
Composite Non-Asbestos Content:	3% Cellulose
Sample Composite Homogeneity:	Poor

Location: 1014B, Black/White 16"x16" Ceramic Floor Tile, Grout and Thin Set

Lab ID-Version‡: 13867719-1

Sample Layers	Asbestos Content
Gray Ceramic Tile with Blue Paint	ND
White Ceramic Tile	ND
Gray Thinset	ND
Brown Paper	ND
Off-White Grout	ND
Composite Non-Asbestos Content:	3% Cellulose
Sample Composite Homogeneity:	Poor

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center East Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022
 Date of Receipt: 04-04-2022
 Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Location: 1014C, Black/White 16"x16" Ceramic Floor Tile, Grout and Thin Set**

Lab ID-Version‡: 13867720-1

Sample Layers	Asbestos Content
Gray Ceramic Tile with Black Paint	ND
White Ceramic Tile	ND
Gray Thinset	ND
Brown Paper	ND
Off-White Grout	ND
Composite Non-Asbestos Content:	3% Cellulose
Sample Composite Homogeneity:	Poor

Location: 1015A, White 2"x2" Ceramic Wall Tile, Grout, Thin Set and Brown Glue

Lab ID-Version‡: 13867721-1

Sample Layers	Asbestos Content
White Ceramic Tile	ND
Off-White Grout	ND
White Thinset	ND
Brown Mastic	ND
Brown Paper	ND
Composite Non-Asbestos Content:	3% Cellulose
Sample Composite Homogeneity:	Moderate

Location: 1015B, White 2"x2" Ceramic Wall Tile, Grout, Thin Set and Brown Glue

Lab ID-Version‡: 13867722-1

Sample Layers	Asbestos Content
White Ceramic Tile	ND
Light Gray Grout	ND
White Thinset	ND
Brown Mastic	ND
Brown Paper	ND
Black Mastic	ND
Composite Non-Asbestos Content:	3% Cellulose
Sample Composite Homogeneity:	Moderate

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center East Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022

Date of Receipt: 04-04-2022

Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Location: 1015C, White 2"x2" Ceramic Wall Tile, Grout, Thin Set and Brown Glue**

Lab ID-Version‡: 13867723-1

Sample Layers	Asbestos Content
White Ceramic Tile	ND
Off-White Grout	ND
White Thinset	ND
Brown Mastic	ND
Brown Paper	ND
Black Mastic	ND
Black Tape	ND
Composite Non-Asbestos Content:	3% Cellulose
Sample Composite Homogeneity:	Moderate

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center East Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022

Date of Receipt: 04-04-2022

Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Location: 1016A, Teal 2"x2" Ceramic Wall Tile, Grout, Thin Set and Brown Glue**

Lab ID-Version‡: 13867724-1

Sample Layers	Asbestos Content
Blue-Green Ceramic Tile	ND
White Grout	ND
Light Gray Thinset	ND
Brown Mastic	ND
Brown Paper	ND
White Joint Compound	ND
Composite Non-Asbestos Content:	3% Cellulose
Sample Composite Homogeneity:	Poor

Location: 1016B, Teal 2"x2" Ceramic Wall Tile, Grout, Thin Set and Brown Glue

Lab ID-Version‡: 13867725-1

Sample Layers	Asbestos Content
Blue-Green Ceramic Tile	ND
White Grout	ND
Light Gray Thinset	ND
Brown Mastic	ND
Brown Paper	ND
White Joint Compound	ND
Composite Non-Asbestos Content:	3% Cellulose
Sample Composite Homogeneity:	Poor

Location: 1016C, Teal 2"x2" Ceramic Wall Tile, Grout, Thin Set and Brown Glue

Lab ID-Version‡: 13867726-1

Sample Layers	Asbestos Content
Blue-Green Ceramic Tile	ND
White Grout	ND
Light Gray Thinset	ND
Brown Mastic	ND
Brown Paper	ND
White Joint Compound	ND
Composite Non-Asbestos Content:	6% Cellulose
Sample Composite Homogeneity:	Poor

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center East Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022

Date of Receipt: 04-04-2022

Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Location: 1017A, Off White 2"x2" Ceramic Floor Tile, Grout, Thin Set and Brown Glue**

Lab ID-Version‡: 13867727-1

Sample Layers	Asbestos Content
Off-White Ceramic Tile	ND
Black Grout	ND
Gray Thinset	ND
Brown Mastic	ND
Composite Non-Asbestos Content:	< 1% Cellulose < 1% Glass Fibers
Sample Composite Homogeneity:	Moderate

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center East Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022

Date of Receipt: 04-04-2022

Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Location: 1017B, Off White 2"x2" Ceramic Floor Tile, Grout, Thin Set and Brown Glue**

Lab ID-Version‡: 13867728-1

Sample Layers	Asbestos Content
Off-White Ceramic Tile	ND
Black Grout	ND
Gray Thinset	ND
Brown Mastic	ND
Composite Non-Asbestos Content:	< 1% Cellulose < 1% Glass Fibers
Sample Composite Homogeneity:	Moderate

Location: 1017C, Off White 2"x2" Ceramic Floor Tile, Grout, Thin Set and Brown Glue

Lab ID-Version‡: 13867729-1

Sample Layers	Asbestos Content
Off-White Ceramic Tile	ND
Black Grout	ND
Gray Thinset	ND
Brown Mastic	ND
Composite Non-Asbestos Content:	< 1% Cellulose < 1% Glass Fibers
Sample Composite Homogeneity:	Moderate

Location: 1018A, Dark Brown 2"x2" Ceramic Floor Tile, Grout, Thin Set and Brown Glue

Lab ID-Version‡: 13867730-1

Sample Layers	Asbestos Content
Black Ceramic Tile	ND
White Ceramic Tile	ND
Black Grout	ND
Gray Thinset	ND
White Grout	ND
Brown Mastic	ND
Composite Non-Asbestos Content:	< 1% Cellulose
Sample Composite Homogeneity:	Moderate

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center East Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022
 Date of Receipt: 04-04-2022
 Date of Report: 04-07-2022

ASBESTOS PLM REPORT

Location: 1018B, Dark Brown 2"x2" Ceramic Floor Tile, Grout, Thin Set and Brown Glue

Lab ID-Version‡: 13867731-1

Sample Layers	Asbestos Content
Black Grout	ND
Gray Thinset	ND
White Grout	ND
Composite Non-Asbestos Content:	< 1% Cellulose
Sample Composite Homogeneity:	Moderate

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center East Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022

Date of Receipt: 04-04-2022

Date of Report: 04-07-2022

ASBESTOS PLM REPORT

Location: 1018C, Dark Brown 2"x2" Ceramic Floor Tile, Grout, Thin Set and Brown Glue

Lab ID-Version‡: 13867732-1

Sample Layers	Asbestos Content
Black Ceramic Tile	ND
Black Grout	ND
Gray Thinset	ND
Brown Mastic	ND
Composite Non-Asbestos Content:	< 1% Cellulose
Sample Composite Homogeneity:	Moderate

Location: 1019A, White/Black 2"x2" Ceramic Wall Tile, Grout and Brown Glue

Lab ID-Version‡: 13867733-1

Sample Layers	Asbestos Content
Black/White Ceramic Tile	ND
White Grout	ND
Brown Mastic	ND
Composite Non-Asbestos Content:	< 1% Cellulose
Sample Composite Homogeneity:	Moderate

Location: 1019B, White/Black 2"x2" Ceramic Wall Tile, Grout and Brown Glue

Lab ID-Version‡: 13867734-1

Sample Layers	Asbestos Content
Black/White Ceramic Tile	ND
White Grout	ND
Brown Mastic	ND
Composite Non-Asbestos Content:	< 1% Cellulose
Sample Composite Homogeneity:	Moderate

Location: 1019C, White/Black 2"x2" Ceramic Wall Tile, Grout and Brown Glue

Lab ID-Version‡: 13867735-1

Sample Layers	Asbestos Content
Black/White Ceramic Tile	ND
White Grout	ND
Brown Mastic	ND
Composite Non-Asbestos Content:	< 1% Cellulose
Sample Composite Homogeneity:	Moderate

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center East Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022

Date of Receipt: 04-04-2022

Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Location: 1020A, Red Fire Putty**

Lab ID-Version‡: 13867736-1

Sample Layers	Asbestos Content
Blue-Green Paint	ND
Red Fireproofing	ND
Composite Non-Asbestos Content:	10% Glass Fibers
Sample Composite Homogeneity:	Good

Location: 1020B, Red Fire Putty

Lab ID-Version‡: 13867737-1

Sample Layers	Asbestos Content
Blue-Green Paint	ND
Red Fireproofing	ND
Composite Non-Asbestos Content:	10% Glass Fibers
Sample Composite Homogeneity:	Good

Location: 1020C, Red Fire Putty

Lab ID-Version‡: 13867738-1

Sample Layers	Asbestos Content
Blue-Green Paint	ND
Red Fireproofing	ND
Composite Non-Asbestos Content:	10% Glass Fibers
Sample Composite Homogeneity:	Good

Location: 1021A, Brown Sprayed on Wall Insulation

Lab ID-Version‡: 13867739-1

Sample Layers	Asbestos Content
Brown Insulation	ND
Composite Non-Asbestos Content:	90% Cellulose
Sample Composite Homogeneity:	Moderate

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center East Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022

Date of Receipt: 04-04-2022

Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Location: 1021B, Brown Sprayed on Wall Insulation**

Lab ID-Version‡: 13867740-1

Sample Layers	Asbestos Content
Brown Insulation	ND
Composite Non-Asbestos Content:	90% Cellulose
Sample Composite Homogeneity:	Moderate

Location: 1021C, Brown Sprayed on Wall Insulation

Lab ID-Version‡: 13867741-1

Sample Layers	Asbestos Content
Brown Insulation	ND
Composite Non-Asbestos Content:	90% Cellulose
Sample Composite Homogeneity:	Moderate

Location: 1022A, Grey Mastic on Metal HVAC Ducts

Lab ID-Version‡: 13867742-1

Sample Layers	Asbestos Content
Gray Mastic	ND
Sample Composite Homogeneity:	Good

Location: 1022B, Grey Mastic on Metal HVAC Ducts

Lab ID-Version‡: 13867743-1

Sample Layers	Asbestos Content
Gray Mastic	ND
Sample Composite Homogeneity:	Good

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center East Building; 501 Seabreeze
 Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022

Date of Receipt: 04-04-2022

Date of Report: 04-07-2022

ASBESTOS PLM REPORT**Location: 1022C, Grey Mastic on Metal HVAC Ducts**

Lab ID-Version‡: 13867744-1

Sample Layers	Asbestos Content
Gray Mastic	ND
Sample Composite Homogeneity: Good	

Location: 1023A, Black 12"x12" Ceramic Floor Tile, Thin Set and Brown Glue

Lab ID-Version‡: 13867745-1

Sample Layers	Asbestos Content
Black Ceramic Tile	ND
White Thinset	ND
Brown Mastic	ND
Sample Composite Homogeneity: Moderate	

Location: 1023B, Black 12"x12" Ceramic Floor Tile, Thin Set and Brown Glue

Lab ID-Version‡: 13867746-1

Sample Layers	Asbestos Content
Black Ceramic Tile	ND
White Thinset	ND
Brown Mastic	ND
Sample Composite Homogeneity: Moderate	

Location: 1023C, Black 12"x12" Ceramic Floor Tile, Thin Set and Brown Glue

Lab ID-Version‡: 13867747-1

Sample Layers	Asbestos Content
Black Ceramic Tile	ND
White Thinset	ND
Brown Mastic	ND
Sample Composite Homogeneity: Moderate	

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

APPENDIX B

PCL ANALYTICAL LABORATORY RESULTS

Report for:

Mr. Sergio Adasme
Terracon - Fort Lauderdale, FL
5371 NW 33rd Ave.
Suite 201
Fort Lauderdale, FL 33309

Regarding: Project: Aquatic Center East & West Buildings; 501 Seabreeze Blvd. Fort Lauderdale, FL
EML ID: 2890696

Approved by:



Laboratory Manager
Danny Li

Dates of Analysis:

Lead - Flame AA: 04-11-2022

Service SOPs: Lead - Flame AA (EM-BC-S-8443)
AIHA-LAP, LLC accredited service, Lab ID #178697

All samples were received in acceptable condition unless noted in the Report Comments portion in the body of the report. Due to the nature of the analyses performed, field blank correction of results is not applied. The results relate only to the samples as received and tested. Sample size, as it relates to Wipe samples only, is supplied by the client.

Eurofins EMLab P&K ("the Company") shall have no liability to the client or the client's customer with respect to decisions or recommendations made, actions taken or courses of conduct implemented by either the client or the client's customer as a result of or based upon the Test Results. In no event shall the Company be liable to the client with respect to the Test Results except for the Company's own willful misconduct or gross negligence nor shall the Company be liable for incidental or consequential damages or lost profits or revenues to the fullest extent such liability may be disclaimed by law, even if the Company has been advised of the possibility of such damages, lost profits or lost revenues. In no event shall the Company's liability with respect to the Test Results exceed the amount paid to the Company by the client therefor.

Eurofins EMLab P&K's LabServe® reporting system includes automated fail-safes to ensure that all AIHA-LAP, LLC quality requirements are met and notifications are added to reports when any quality steps remain pending.

Client: Terracon - Fort Lauderdale, FL
C/O: Mr. Sergio Adasme
Re: Aquatic Center East & West Buildings; 501
Seabreeze Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022
Date of Receipt: 04-04-2022
Date of Report: 04-11-2022

LEAD: FLAME ATOMIC ABSORPTION SPECTROMETRY

Location:	L1: White Exterior Stucco- West Bldg.	L2: White Drywall and Joint Compound Walls- West Bldg.	L3: White Plaster Walls- West Bldg.	L4: White Metal Door Frames- West Bldg.
Comments (see below)	None	None	None	None
Lab ID-Version‡:	13867126-1	13867127-1	13867128-1	13867129-1
Analysis Date:	04/11/2022	04/11/2022	04/11/2022	04/11/2022
Sample type	Paint Chip sample	Paint Chip sample	Paint Chip sample	Paint Chip sample
Method*	NIOSH 7082 & EPA 7000B modified	NIOSH 7082 & EPA 7000B modified	NIOSH 7082 & EPA 7000B modified	NIOSH 7082 & EPA 7000B modified
† Method Reporting Limit	39 ppm	40 ppm	39 ppm	40 ppm
Sample size	0.2569 grams	0.2507 grams	0.2595 grams	0.2522 grams
§Total Lead Result	< 39 ppm	< 40 ppm	< 39 ppm	2200 ppm

Comments:

Sample results have not been corrected for blank values.

Bulk samples are not covered under the AIHA-LAP, LLC service accreditation.

Wipe samples must meet ASTM E1792 criteria. Method Reporting Limits may not be valid for non-ASTM E1792 wipe samples.

*Sample preparation and analytical methods are based upon NIOSH 7082 and EPA 7000B.

† The Method Reporting Limit is the minimum concentration of Lead that the laboratory can confidently detect in the sample.

§ Total Lead Result has been rounded to two significant figures to reflect analytical precision.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center East & West Buildings; 501
 Seabreeze Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022
 Date of Receipt: 04-04-2022
 Date of Report: 04-11-2022

LEAD: FLAME ATOMIC ABSORPTION SPECTROMETRY

Location:	L5: White Wood Doors- West Bldg.	L6: Green Metal Display Racks- West Bldg.	L7: Blue Metal Display Racks- West Bldg.	L8: Pink Drywall and Joint Compound Walls- West Bldg.
Comments (see below)	None	None	None	None
Lab ID-Version‡:	13867130-1	13867131-1	13867132-1	13867133-1
Analysis Date:	04/11/2022	04/11/2022	04/11/2022	04/11/2022
Sample type	Paint Chip sample	Paint Chip sample	Paint Chip sample	Paint Chip sample
Method*	NIOSH 7082 & EPA 7000B modified	NIOSH 7082 & EPA 7000B modified	NIOSH 7082 & EPA 7000B modified	NIOSH 7082 & EPA 7000B modified
† Method Reporting Limit	70 ppm	120 ppm	140 ppm	39 ppm
Sample size	0.1426 grams	0.0852 grams	0.0723 grams	0.2589 grams
§Total Lead Result	< 70 ppm	< 120 ppm	< 140 ppm	< 39 ppm

Comments:

Sample results have not been corrected for blank values.

Bulk samples are not covered under the AIHA-LAP, LLC service accreditation.

Wipe samples must meet ASTM E1792 criteria. Method Reporting Limits may not be valid for non-ASTM E1792 wipe samples.

*Sample preparation and analytical methods are based upon NIOSH 7082 and EPA 7000B.

† The Method Reporting Limit is the minimum concentration of Lead that the laboratory can confidently detect in the sample.

§ Total Lead Result has been rounded to two significant figures to reflect analytical precision.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
C/O: Mr. Sergio Adasme
Re: Aquatic Center East & West Buildings; 501
Seabreeze Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022
Date of Receipt: 04-04-2022
Date of Report: 04-11-2022

LEAD: FLAME ATOMIC ABSORPTION SPECTROMETRY

Location:	L9: Grey Drywall and Joint Compound Walls- West Bldg.	L10: White Exterior Stucco- East Bldg.	L11: Pink Exterior Stucco- East Bldg.	L12: Black Exterior Concrete Columns- East Bldg.
Comments (see below)	None	None	None	None
Lab ID-Version‡:	13867134-1	13867135-1	13867136-1	13867137-1
Analysis Date:	04/11/2022	04/11/2022	04/11/2022	04/11/2022
Sample type	Paint Chip sample	Paint Chip sample	Paint Chip sample	Paint Chip sample
Method*	NIOSH 7082 & EPA 7000B modified	NIOSH 7082 & EPA 7000B modified	NIOSH 7082 & EPA 7000B modified	NIOSH 7082 & EPA 7000B modified
† Method Reporting Limit	40 ppm	40 ppm	40 ppm	40 ppm
Sample size	0.2527 grams	0.2513 grams	0.2510 grams	0.2525 grams
§Total Lead Result	< 40 ppm	< 40 ppm	< 40 ppm	< 40 ppm

Comments:

Sample results have not been corrected for blank values.

Bulk samples are not covered under the AIHA-LAP, LLC service accreditation.

Wipe samples must meet ASTM E1792 criteria. Method Reporting Limits may not be valid for non-ASTM E1792 wipe samples.

*Sample preparation and analytical methods are based upon NIOSH 7082 and EPA 7000B.

† The Method Reporting Limit is the minimum concentration of Lead that the laboratory can confidently detect in the sample.

§ Total Lead Result has been rounded to two significant figures to reflect analytical precision.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
C/O: Mr. Sergio Adasme
Re: Aquatic Center East & West Buildings; 501
Seabreeze Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022
Date of Receipt: 04-04-2022
Date of Report: 04-11-2022

LEAD: FLAME ATOMIC ABSORPTION SPECTROMETRY

Location:	L13: Green Exterior Metal Window Frame- East Bldg.	L14: Grey Exterior Concrete Walls- East Bldg.	L15: Blue Exterior Stucco Roof- East Bldg.	L16: Green Interior Metal Staircase- East Bldg.
Comments (see below)	None	None	None	None
Lab ID-Version‡:	13867138-1	13867139-1	13867140-1	13867141-1
Analysis Date:	04/11/2022	04/11/2022	04/11/2022	04/11/2022
Sample type	Paint Chip sample	Paint Chip sample	Paint Chip sample	Paint Chip sample
Method*	NIOSH 7082 & EPA 7000B modified	NIOSH 7082 & EPA 7000B modified	NIOSH 7082 & EPA 7000B modified	NIOSH 7082 & EPA 7000B modified
† Method Reporting Limit	57 ppm	39 ppm	40 ppm	39 ppm
Sample size	0.1740 grams	0.2539 grams	0.2525 grams	0.2567 grams
§Total Lead Result	< 57 ppm	< 39 ppm	< 40 ppm	120 ppm

Comments:

Sample results have not been corrected for blank values.

Bulk samples are not covered under the AIHA-LAP, LLC service accreditation.

Wipe samples must meet ASTM E1792 criteria. Method Reporting Limits may not be valid for non-ASTM E1792 wipe samples.

*Sample preparation and analytical methods are based upon NIOSH 7082 and EPA 7000B.

† The Method Reporting Limit is the minimum concentration of Lead that the laboratory can confidently detect in the sample.

§ Total Lead Result has been rounded to two significant figures to reflect analytical precision.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
 C/O: Mr. Sergio Adasme
 Re: Aquatic Center East & West Buildings; 501
 Seabreeze Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022
 Date of Receipt: 04-04-2022
 Date of Report: 04-11-2022

LEAD: FLAME ATOMIC ABSORPTION SPECTROMETRY

Location:	L17: White Drywall and Joint Compound Walls and Ceilings- East Bldg.	L18: White Metal Door Frames- East Bldg.	L19: White Wood Doors- East Bldg.	L20: White Interior Concrete Block and Mortar Walls- East Bldg.
Comments (see below)	None	None	None	None
Lab ID-Version‡:	13867142-1	13867143-1	13867144-1	13867145-1
Analysis Date:	04/11/2022	04/11/2022	04/11/2022	04/11/2022
Sample type	Paint Chip sample	Paint Chip sample	Paint Chip sample	Paint Chip sample
Method*	NIOSH 7082 & EPA 7000B modified	NIOSH 7082 & EPA 7000B modified	NIOSH 7082 & EPA 7000B modified	NIOSH 7082 & EPA 7000B modified
† Method Reporting Limit	39 ppm	63 ppm	40 ppm	41 ppm
Sample size	0.2586 grams	0.1593 grams	0.2530 grams	0.2425 grams
§ Total Lead Result	< 39 ppm	< 63 ppm	< 40 ppm	< 41 ppm

Comments:

Sample results have not been corrected for blank values.

Bulk samples are not covered under the AIHA-LAP, LLC service accreditation.

Wipe samples must meet ASTM E1792 criteria. Method Reporting Limits may not be valid for non-ASTM E1792 wipe samples.

*Sample preparation and analytical methods are based upon NIOSH 7082 and EPA 7000B.

† The Method Reporting Limit is the minimum concentration of Lead that the laboratory can confidently detect in the sample.

§ Total Lead Result has been rounded to two significant figures to reflect analytical precision.

‡ A "Version" indicated by -"x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Terracon - Fort Lauderdale, FL
C/O: Mr. Sergio Adasme
Re: Aquatic Center East & West Buildings; 501
Seabreeze Blvd. Fort Lauderdale, FL

Date of Sampling: 04-04-2022
Date of Receipt: 04-04-2022
Date of Report: 04-11-2022

LEAD: FLAME ATOMIC ABSORPTION SPECTROMETRY

Location:	L21: Yellow Metal Display Racks- East Bldg.	L22: Blue Metal Display Racks- East Bldg.	L23: Green Metal Display Racks- East Bldg.
Comments (see below)	None	None	None
Lab ID-Version‡:	13867146-1	13867147-1	13867148-1
Analysis Date:	04/11/2022	04/11/2022	04/11/2022
Sample type	Paint Chip sample	Paint Chip sample	Paint Chip sample
Method*	NIOSH 7082 & EPA 7000B modified	NIOSH 7082 & EPA 7000B modified	NIOSH 7082 & EPA 7000B modified
† Method Reporting Limit	79 ppm	97 ppm	130 ppm
Sample size	0.1262 grams	0.1029 grams	0.0747 grams
§Total Lead Result	< 79 ppm	< 97 ppm	< 130 ppm

Comments:

Sample results have not been corrected for blank values.

Bulk samples are not covered under the AIHA-LAP, LLC service accreditation.

Wipe samples must meet ASTM E1792 criteria. Method Reporting Limits may not be valid for non-ASTM E1792 wipe samples.

*Sample preparation and analytical methods are based upon NIOSH 7082 and EPA 7000B.

† The Method Reporting Limit is the minimum concentration of Lead that the laboratory can confidently detect in the sample.

§ Total Lead Result has been rounded to two significant figures to reflect analytical precision.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

APPENDIX C

LICENSES AND CERTIIFICATIONS

