



1. THE UTILITY DESIGN DETAILS SUMMARIZED ON THIS SHEET ARE FOR PROPERTY OWNER REVIEW. THE CONTRACTOR SHALL REFERENCE THE UTILITY DESIGN PACKAGE (UDP), PROVIDED WITH THE "BIDDING FOR CONSTRUCTION" DRAWINGS FOR BIDDING. THE CONTRACTOR SHALL INSTALL THE UTILITY RELATED SCOPE OF WORK PER UTILITY CONSTRUCTION SPECIFICATION REQUIREMENTS. THE ELECTRIC UTILITY DESIGN WITHIN THE UDP SHALL SUPERSEDE ALL OTHER INFORMATION.
2. UTILITY EQUIPMENT INSTALLATIONS AND PREP WORK AND TERMINATION OF SERVICE CONDUCTORS SHALL BE COORDINATED WITH THE APPROPRIATE UTILITY ENGINEER AT TIME OF PRE-CONSTRUCTION MEETING TO ENSURE ACCURACY OF INSTALLATIONS.
3. TRANSFORMER BOLLARD PROTECTION TO BE INSTALLED PER UTILITY SPECIFICATION. ADDITIONAL BOLLARD PROTECTION MAY BE REQUIRED AT THE DISCRETION OF THE UTILITY FIELD INSPECTION PERSONNEL.
4. CONTRACTOR TO CONFIRM ALL CLEARANCES MEET UTILITY REQUIREMENTS.



<p>AMAZON DFH1_EV 6320 NW 12 AVE FORT LAUDERDALE, FL 33309</p> <p>FPL EASEMENT EXHIBIT</p>
<p>SHEET EX-1</p>

INCORPORATED
 ENGINEER CERTIFICATE OF QUALITY (EQC)
 WGI Inc.com
 3025 WEST PARKWAY WEST PALM BEACH, FL 33411