




B Ocean Resort (formerly The Sheraton Fort Lauderdale Beach Hotel)

W

A1A

Connecting cable to be incased in conduit per City of Ft. Lauderdale code, behind light pole.


Distance from the seawall to the north side of the sidewalk is 15' 10".

Proposed B-Station Extension

Single sided, solar powered. 2 bases, 4 docks. 10' 4" station. Secured to new concrete pad (11' 2" long by 24" wide by 5") with approved concrete anchors north of the seawall.

Distance from the back of the bike to the north side of the sidewalk is greater than 10'.

Distance from the seawall to the north side of the sidewalk is 16' 5".



A1A

Atlantic Ocean

N

South Beach Lot -
South End Parking

B Ocean Resort (formerly The
Sheraton Fort Lauderdale
Beach Hotel)

Proposed B-Station Expansion

Single sided, solar powered. 2 bases, 4
docks. 10' 4" station. Secured to new
concrete pad (11' 2" long by 24" wide
by 5") with approved concrete anchors
north of the seawall.

CAM #16-0650


Exhibit 2

Page 2 of 17



B CYCLE STATION STRUCTURAL DRAWINGS FOR MULTIPLE LOCATIONS THROUGHOUT MIAMI-DADE AND BROWARD COUNTIES.

PREPARED BY:



7300 North Kendall Drive, Suite 400
Miami, Florida 33156
Tel: 305.670.2350 Fax: 305.670.2351
Certificate of Authorization No. 7184
www.bcceng.com

INDEX OF DRAWINGS:

S-1.0	GENERAL NOTES
S-2.0	STATION PLAN AND ELEVATION (3 DOCK)
S-2.1	STATION PLAN (MULTIPLE DOCK LAYOUT)

DATE: JULY 14, 2011
REVISION No. 1: SEPTEMBER 26, 2011
REVISION No. 2: NOVEMBER 12, 2012



GENERAL NOTES:

1. THE GOVERNING CODE FOR THIS PROJECT IS THE FLORIDA BUILDING CODE, 2010 EDITION. THIS CODE PRESCRIBES WHICH EDITION OF EACH REFERENCED STANDARD APPLIES TO THIS PROJECT.
2. TO THE BEST OF OUR KNOWLEDGE, THE STRUCTURAL DRAWINGS AND SPECIFICATIONS COMPLY WITH THE APPLICABLE REQUIREMENTS OF THE GOVERNING BUILDING CODE.
3. CONSTRUCTION IS TO COMPLY WITH THE REQUIREMENTS OF THE GOVERNING BUILDING CODE AND ALL OTHER APPLICABLE FEDERAL, STATE, AND LOCAL CODES, STANDARDS, REGULATIONS AND LAWS.
4. THE STRUCTURAL DOCUMENTS ARE TO BE USED IN CONJUNCTION WITH THE PRODUCT DOCUMENTS.
5. CONTRACTORS WHO DISCOVER DISCREPANCIES, OMISSIONS OR VARIATIONS IN THE CONTRACT DOCUMENTS DURING BIDDING SHALL IMMEDIATELY NOTIFY THE ARCHITECT. THE ARCHITECT WILL RESOLVE THE CONDITION AND ISSUE A WRITTEN CLARIFICATION.
6. THE GENERAL CONTRACTOR SHALL COORDINATE ALL CONTRACT DOCUMENTS WITH FIELD CONDITIONS AND DIMENSIONS PRIOR TO CONSTRUCTION.
7. THE CONTRACTOR SHALL PROTECT ADJACENT PROPERTY, HIS OWN WORK AND THE PUBLIC FROM HARM. THE CONTRACTOR IS SOLELY RESPONSIBLE FOR CONSTRUCTION MEANS AND METHODS, AND JOBSITE SAFETY INCLUDING ALL OSHA REQUIREMENTS.


8. DESIGN WIND LOADS

GOVERNING CODE	ASCE 7-10
BASIC WIND SPEED	V = 165 MPH
RISK CATEGORY	I
DIRECTIONALITY FACTOR	Kd = 0.85
EXPOSURE	D


9. MAXIMUM ALLOWABLE SOIL BEARING PRESSURES ARE PRESUMED TO BE 2000 PSF.

EXPANSION ANCHORS:

1. USE GALVANIZED WEDGE-TYPE EXPANSION ANCHORS SUCH AS THE HILTI KWIK BOLT III, ITW RAMSET RED HEAD TRUBOLT WEDGE, SIMPSON STRONG-TIE WEDGE-ALL OR EQUIVALENT. FOLLOW MANUFACTURER'S SPECIFICATIONS FOR USE AND INSTALLATION.
2. PROVIDE ANCHOR EMBEDMENT, SPACING AND EDGE DISTANCE AS SHOWN ON THE DRAWINGS.



Certificate of Authorization No. 7184
7300 North Kendall Drive, Suite 400
Miami, Florida 33156
Tel: 305.670.2350 Fax: 305.670.2351
www.bcceng.com



To the best of my knowledge these plans and specifications comply with the applicable minimum building codes.

STEVEN GOLDSTEIN, P.E.
Florida License No. 44423

Submittals / Revisions

11-16-12	FBC 2010

Drawn: CA

Checked: FD

Reviewed: SG


BCC Project No.: 100571.00

Date: 07-14-11



GENERAL NOTES

S-1.0





Page 10 of 10

Date: 07-14-11

STATION PLAN AND
ELEVATION (3 DOCK)

Page 5 of 17





To the best of my knowledge these plans and specifications comply with the applicable minimum building codes.

STEVEN GOLDSTEIN, P.E.
Florida License No. 44423

Submittals / Revisions

1	09-26-11	OWNER REV.
2	11-16-12	FBC 2010

Drawn: CA

Checked: PD

Reviewed: SG


BCC Project No.: 100571.00

Date: 07-14-11



STATION PLAN (MULTIPLE
DOCK LAYOUT)

S-2.1




B CYCLE STATION PLAN
UP TO 21 DOCK CONFIGURATION - 19"/33"/45" WIDE BASE
SCALE: 3/8" = 1'-0"

REVISED STRUCTURAL CALCULATIONS FOR




**Stations throughout
Miami-Dade and Broward County**

Prepared by:




**BCC Engineering, Inc.
Certificate of Authorization No. 7184
November 16, 2012- Revision 2**

**Calculations have been prepared by the undersigned engineer assuming
responsibility for manual and computer generated information.**




BCC ENGINEERING, INC. • 7300 N. Kendall Drive, Suite 400 • Miami, FL 33156 • Phone (305) 670-2350 • Fax (305) 670-2351




BCC ENGINEERING, INC.
7300 N. Kendall Drive
Suite 400
Miami, Florida 33156
t. 305.670.2350
f. 305.670.2351

JOB **B CYCLE WIND ANALYSIS**
SHEET No. _____ OF _____ JOB No. **100571.00**
CALCULATED BY **JJF** DRAWN BY _____
SCALE _____ DATE **11/10**



B CYCLE STATION FRONT ELEVATION
3 DOCK CONFIGURATION - 33"/45" WIDE BASE

B Cycle stations have multiple configurations from 3 to 21 docks in linear or variations of 45 deg. angle layouts. Of all configurations, the one shown above is the controlling case (single 3 dock station).



JOB# 0100571.00 SHEET No OF 2
PROJECT NAME BCycle
SUBJECT Foundation slab
CALCULATED BY SG DATE 11/12/12
CHECKED BY DATE

Governing Code: IBC 2010
Governing Wind Load Standard: 7-10

Risk Category I

Location: Miami-Dade or Broward County
Design for worst case - Miami-Dade County
V = 165 MPH

Exposure = C or D depending on location
Design for worst case - Exposure D

$K_{zt} = 1.0$

Height = 7'-5" < 15' $\Rightarrow K_z = 1.03$

Load case A: Wind in short direction (wind acts on kiosk, 3 docks & narrow face of sign)

Load case B: Wind in long direction (wind acts on kiosk, 3 docks & broad face of sign)

Wind load for load case B slightly higher than for load case A, but by inspection, foundation loading much more critical for load case A due to much narrower base resisting overturning moment

Consider kiosk, docks and narrow face of sign as "Chimneys, Tanks, Similar Structures" (square) $\Rightarrow K_d = 0.90$


$$q_z = (1.00256)(1.03)(1.0)(0.90)(165)^2 = 69.6 \text{ psf}$$

$$G = 0.85$$

$$h/D_{\text{kiosk}} = 7.42/1.25 = 5.9 \quad C_f = 1.38$$

$$h/D_{\text{sign}} = 6.58/1.25 = 5.26 \quad C_f = 2.0$$

$$h/D_{\text{dock}} = 2.67/0.33 = 8 \quad C_f = 1.43$$



JOB# 0100571.00 SHEET No OF 3
PROJECT NAME B Cycle
SUBJECT Foundation Slab
CALCULATED BY SG DATE 11/12/12
CHECKED BY DATE

Wind pressure

$$\text{Kiosk: } (64.6)(0.85)(1.38) = 75.8 \text{ psf}$$

$$\text{Sign: } (64.6)(.85)(2.0) = 110 \text{ psf}$$

$$\text{Dock: } (64.6)(.85)(1.43) = 78.5 \text{ psf}$$

Total shear

$$(9.1)(75.8) + (1.6)(110) + (3)(1.7)(78.5) = 690 + 176 + 401 = 1267 \text{ lb}$$

$$\text{Overturning moment} = (690)\left(\frac{7.42}{2}\right) + 176\left(\frac{6.58}{2}\right) + 401\left(\frac{2.67}{2}\right) = 3672 \text{ ft-lb}$$

For allowable stress design use 0.6 load factor

$$M_o = 0.6(3672) = 2203 \text{ ft-lb} \quad V = (1267)(0.6) = 760 \text{ lb}$$

Weight

$$\text{Kiosk} = 170 \text{ lb}$$

$$\text{Dock} \quad 3 \times 58 = 174 \text{ lb}$$

$$\text{Base} \quad \underline{95 \text{ lb}}$$

$$439 \text{ lb}$$

$$\text{For 19" base } M_{\text{resisting}} = 439 \times \frac{19}{12} / 2 = 347 \text{ ft-lb} \times 0.6 = 209 \text{ ft-lb}$$

$$\text{Net overturning moment to be resisted by anchors} = 2203 - 209 = 1994 \text{ ft-lb}$$

Use 3 anchors per side (6 total) spaced at 10", edge distance = 6" min.

$$\text{Shear per anchor} = 760 / 6 = 127 \text{ lb}$$

$$\text{Tension per anchor} = 1994 / (3)(0.83) = 798 \text{ lb}$$

Assume existing concrete $f'_c = 2000 \text{ psi}$ (conservative)

Use 1/2" dia wedge anchors (Wedge-All) by Simpson, or equivalent


$$\text{Allowable tension} = 1510 \text{ lb}$$

$$\text{Allowable shear} = 1675 \text{ lb}$$

No spacing or edge distance factors required

} See attached catalog tables

$$\text{Interaction: } \frac{798}{1510} + \frac{127}{1675} = 0.60 < 1 \quad \text{O.K.}$$



JOB# 0100571.00 SHEET No OF 4
PROJECT NAME B Cycle
SUBJECT Foundation slab
CALCULATED BY SG DATE 11/12/12
CHECKED BY DATE

At stations without kiosk

$$\text{Total shear} = (1.6)(110) + 3(1.7)(78.5) = 176 + 401 = 577 \text{ lb}$$

$$\text{Overturning moment} = 176 \left(\frac{6.58}{2} \right) + 401 \left(\frac{2.67}{2} \right) = 1114 \text{ ft-lb}$$

For allowable stress design

$$M_u = 0.6(1114) = 668 \text{ ft-lb} \quad V = (577)(0.6) = 347 \text{ lb}$$

$$\text{Weight} = 174 + 95 = 269 \text{ lb}$$

$$M_{\text{resisting}} = 269 \times \frac{14}{12} / 2 = 212 \text{ ft-lb} \times 0.6 = 127 \text{ ft-lb}$$

$$\text{Net overturning moment to be resisted by anchors} = 668 - 127 = 541 \text{ ft-lb}$$


$$\text{Shear per anchor} = 347 / 4 = 87 \text{ lb}$$

$$\text{Tension per anchor} = 541 / 2(0.83) = 324 \text{ lb}$$

Forces less critical than for station with kiosk

Simpson Strong-Tie® Anchoring and Fastening Systems for Concrete and Masonry

Wedge-All® Wedge Anchors



**Tension Loads for Carbon-Steel Wedge-All® (and Tie-Wire) Anchors
in Normal-Weight Concrete**



Size in. (mm)	Embed Depth in. (mm)	Critical Edge Dist. in. (mm)	Critical Spacing in. (mm)	Tension Load									Install Torque ft-lbs (N-m)
				f _c ≥ 2000 psi (13.8 MPa) Concrete			f _c ≥ 3000 psi (20.7 MPa) Concrete		f _c ≥ 4000 psi (27.6 MPa) Concrete				
				Ultimate lbs. (kN)	Std. Dev. lbs. (kN)	Allowable lbs. (kN)	Allowable lbs. (kN)	Ultimate lbs. (kN)	Std. Dev. lbs. (kN)	Allowable lbs. (kN)			
1/4 (6.4)	1 1/4 (29)	2 1/4 (64)	1 1/4 (41)	680 (3.0)	167 (0.7)	170 (0.8)	205 (0.9)	960 (4.3)	233 (1.0)	240 (1.1)	8 (10.8)		
	2 1/4 (57)	2 1/4 (64)	3 1/4 (79)	1,920 (8.5)	286 (1.3)	480 (2.1)	530 (2.4)	2,320 (10.3)	105 (0.5)	580 (2.6)			
3/8 (9.5)	1 1/4 (44)	3 1/4 (95)	2 1/4 (60)	1,560 (6.9)	261 (1.2)	300 (1.3)	555 (2.5)	2,400 (10.7)	505 (2.3)	720 (3.2)	20 (26.7)		
	2 1/4 (57)	3 1/4 (95)	3 1/4 (92)	3,360 (14.9)	404 (2.1)	840 (3.7)	1,180 (5.3)	5,440 (24.2)	593 (2.7)	1,360 (6.0)			
	3 1/4 (86)	3 1/4 (95)	4 1/4 (121)	3,680 (16.4)	585 (2.6)	920 (4.1)	1,340 (5.9)	5,440 (24.2)	818 (3.6)	1,360 (6.0)			
1/2 (12.7)	2 1/4 (57)	5 (127)	3 1/4 (79)	3,280 (14.6)	871 (3.9)	820 (3.6)	1,070 (4.8)	5,280 (23.5)	849 (3.8)	1,320 (5.9)	60 (81.3)		
	3 1/4 (86)	5 (127)	4 1/4 (121)	6,040 (26.9)	654 (2.9)	1,510 (6.7)	1,985 (8.8)	9,840 (43.8)	1,303 (5.8)	2,460 (10.9)			
	4 1/4 (114)	5 (127)	6 1/4 (159)	6,960 (31.0)	839 (3.7)	1,740 (7.7)	2,350 (10.5)	11,840 (52.7)	2,462 (11.0)	2,960 (13.2)			
5/8 (15.9)	2 1/4 (57)	6 1/4 (159)	3 1/4 (92)	4,520 (20.3)	120 (0.5)	1,130 (5.0)	1,640 (7.3)	8,800 (39.3)	729 (3.2)	2,150 (9.6)	90 (122.0)		
	4 1/4 (114)	6 1/4 (159)	6 1/4 (159)	8,200 (36.5)	612 (2.7)	2,060 (9.1)	2,990 (13.3)	15,720 (69.9)	1,224 (5.4)	3,980 (17.5)			
	5 1/4 (140)	6 1/4 (159)	7 1/4 (197)	9,200 (40.9)	650 (2.9)	2,060 (9.1)	2,990 (13.3)	15,720 (69.9)	1,116 (5.0)	3,930 (17.5)			
3/4 (19.1)	3 1/4 (86)	7 1/4 (191)	4 1/4 (121)	6,760 (30.1)	1,452 (6.5)	1,690 (7.5)	2,090 (9.3)	9,960 (44.3)	1,324 (5.9)	2,490 (11.1)	150 (203.4)		
	5 (127)	7 1/4 (191)	7 (178)	10,040 (44.7)	544 (2.4)	2,510 (11.2)	3,225 (14.3)	15,760 (70.1)	1,550 (6.9)	3,940 (17.5)			
	6 1/4 (171)	7 1/4 (191)	9 1/4 (241)	10,040 (44.7)	1,588 (7.1)	2,510 (11.2)	3,380 (15.0)	17,000 (75.6)	1,668 (7.4)	4,250 (18.9)			
7/8 (22.2)	3 1/4 (86)	8 1/4 (222)	5 1/4 (137)	7,480 (33.3)	821 (3.7)	1,870 (8.3)	2,275 (10.1)	10,720 (47.7)	1,253 (5.6)	2,480 (11.0)	200 (271.2)		
	7 1/4 (200)	8 1/4 (222)	11 (279)	17,040 (75.8)	1,566 (7.0)	4,260 (18.9)	4,675 (20.8)	20,320 (90.4)	2,401 (10.7)	5,680 (25.3)			
1 (25.4)	4 1/4 (114)	10 (254)	6 1/4 (159)	15,400 (68.5)	2,440 (10.9)	3,850 (17.1)	3,885 (17.3)	15,680 (69.7)	1,876 (8.3)	3,920 (17.4)	300 (406.7)		
	9 (229)	10 (254)	12 1/4 (321)	20,760 (92.3)	3,116 (13.9)	5,190 (23.1)	6,365 (28.3)	30,080 (133.8)	1,612 (7.2)	7,520 (33.5)			
1 1/4 (31.8)	5 1/4 (143)	12 1/4 (318)	7 1/4 (203)	18,760 (83.4)	1,345 (6.0)	3,780 (16.9)	4,890 (21.8)	24,760 (110.3)	2,261 (10.1)	8,190 (36.5)	400 (542.3)		
	9 1/4 (241)	12 1/4 (318)	13 1/4 (337)	20,360 (89.7)	3,260 (14.5)	5,440 (24.2)	6,635 (29.4)	40,880 (181.6)	1,608 (7.2)	12,240 (54.4)			


1. The allowable loads listed are based on a safety factor of 4.0.
2. Refer to allowable load-adjustment factors for edge distance and spacing on pages 141 and 143.
3. Drill bit diameter used in base material corresponds to nominal anchor diameter.
4. Allowable loads may be linearly interpolated between concrete strengths listed.
5. Allowable loads for 1/4-inch size at 1 1/4-inch embedment apply to both the Wedge-All® and Tie-Wire anchors. Installation torque does not apply to the Tie-Wire anchor.
6. The minimum concrete thickness is 1 1/4 times the embedment depth.

*See page 13 for an explanation of the load table icons

Mechanical Anchors

Simpson Strong-Tie® Anchoring and Fastening Systems for Concrete and Masonry

Wedge-All® Wedge Anchors



Shear Loads for Carbon-Steel Wedge-All® (and Tie-Wire) Anchors
in Normal-Weight Concrete



Size In. (mm)	Embed Depth In. (mm)	Critical Edge Dist. In. (mm)	Critical Spacing In. (mm)	Shear Load					Install Torque ft.-lb. (N-m)
				f _c ≥ 2000 psi (13.8 MPa) Concrete			f _c ≥ 3000 psi (20.7 MPa) Concrete	f _c ≥ 4000 psi (27.6 MPa) Concrete	
				Ultimate lbs. (kN)	Std. Dev. lbs. (kN)	Allowable lbs. (kN)	Allowable lbs. (kN)	Allowable lbs. (kN)	
1/4 (6.4)	1 1/4 (29)	2 1/4 (64)	1 1/4 (41)	920 (4.1)	47 (0.2)	230 (1.0)	230 (1.0)	230 (1.0)	8 (10.8)
	2 1/4 (57)	2 1/4 (64)	3 1/4 (79)	.	.	230 (1.0)	230 (1.0)	230 (1.0)	
1/4 (9.5)	1 1/4 (44)	3 1/4 (85)	2 1/4 (60)	2,280 (10.1)	95 (0.4)	570 (2.5)	570 (2.5)	570 (2.5)	30 (40.7)
	2 1/4 (57)	3 1/4 (85)	3 1/4 (82)	4,220 (18.9)	388 (1.7)	1,065 (4.7)	1,065 (4.7)	1,065 (4.7)	
	3 1/4 (86)	3 1/4 (85)	4 1/4 (121)	.	.	1,065 (4.7)	1,065 (4.7)	1,065 (4.7)	
1/2 (12.7)	2 1/4 (57)	5 (127)	3 1/4 (79)	6,560 (29.2)	850 (3.8)	1,345 (6.0)	1,485 (6.6)	1,625 (7.2)	50 (81.3)
	3 1/4 (86)	5 (127)	4 1/4 (121)	8,160 (36.3)	880 (3.9)	1,675 (7.5)	1,850 (8.2)	2,020 (9.0)	
	4 1/4 (114)	5 (127)	6 1/4 (159)	.	.	1,675 (7.5)	1,850 (8.2)	2,020 (9.0)	
3/8 (15.9)	2 1/4 (70)	6 1/4 (159)	3 1/4 (98)	8,720 (38.8)	1,699 (7.6)	1,620 (7.2)	1,900 (8.5)	2,180 (9.7)	90 (122.0)
	4 1/4 (114)	6 1/4 (159)	6 1/4 (159)	12,570 (55.9)	388 (1.3)	2,330 (10.4)	2,740 (12.2)	3,145 (14.0)	
	5 1/4 (140)	6 1/4 (159)	7 1/4 (187)	.	.	2,330 (10.4)	2,740 (12.2)	3,145 (14.0)	
3/4 (19.1)	3 1/4 (86)	7 1/4 (191)	4 1/4 (121)	11,360 (50.5)	792 (3.5)	2,840 (12.6)	2,840 (12.6)	2,840 (12.6)	150 (203.4)
	5 (127)	7 1/4 (191)	7 (178)	18,430 (82.0)	1,821 (8.5)	4,610 (20.5)	4,610 (20.5)	4,610 (20.5)	
	6 1/4 (171)	7 1/4 (191)	9 1/4 (241)	.	.	4,610 (20.5)	4,610 (20.5)	4,610 (20.5)	
3/4 (22.2)	3 1/4 (98)	8 1/4 (212)	5 1/4 (137)	13,760 (61.2)	2,059 (9.2)	3,440 (15.3)	3,440 (15.3)	3,440 (15.3)	200 (271.2)
	7 1/4 (200)	8 1/4 (212)	11 (279)	21,300 (95.2)	477 (2.1)	5,970 (26.6)	6,675 (29.8)	7,575 (29.8)	
1 (25.4)	4 1/4 (114)	10 (254)	6 1/4 (159)	22,519 (100.2)	1,156 (5.1)	5,730 (25.5)	5,730 (25.5)	5,730 (25.5)	300 (406.7)
	9 (229)	10 (254)	12 1/4 (321)	25,380 (112.9)	729 (3.2)	6,345 (28.2)	6,345 (28.2)	6,345 (28.2)	
1 1/4 (31.8)	5 1/4 (143)	12 1/4 (318)	7 1/4 (200)	29,320 (130.4)	2,009 (9.3)	7,330 (32.6)	7,330 (32.6)	7,330 (32.6)	400 (542.3)
	9 1/4 (241)	12 1/4 (318)	15 1/4 (397)	.	.	7,330 (32.6)	7,330 (32.6)	7,330 (32.6)	


1. The allowable loads listed are based on a safety factor of 4.0.
2. Refer to allowable load-adjustment factors for spacing and edge distance on pages 141, 142 and 144.
3. Drill bit diameter used in base material corresponds to nominal anchor diameter.
4. Allowable loads may be linearly interpolated between concrete strengths listed.
5. Allowable loads for 1/4-inch size at 1 1/4-inch embedment apply to both the Wedge-All® and Tie-Wire anchors.
Installation torque does not apply to the Tie-Wire anchor.
6. The minimum concrete thickness is 1 1/2 times the embedment depth.

*See page 13 for
an explanation
of the load table
icons

Mechanical Anchors

Simpson Strong-Tie® Anchoring and Fastening Systems for Concrete and Masonry

Wedge-All® Technical Information



Load-Adjustment Factors for Carbon-Steel and Stainless-Steel Wedge-All® Anchors in Normal-Weight Concrete:
Edge Distance, Tension and Shear Loads

- How to use these charts:
1. The following tables are for reduced edge distance.
 2. Locate the anchor size to be used for either a tension and/or shear load application.
 3. Locate the edge distance (C_{act}) at which the anchor is to be installed.
 4. The load adjustment factor (f_c) is the intersection of the row and column.
 5. Multiply the allowable load by the applicable load adjustment factor.
 6. Reduction factors for multiple edges are multiplied together.

Edge Distance Tension (f_c)



Edge Dist. C_{act} (in.)	Size	1/4	3/8	1/2	5/8	3/4	7/8	1	1 1/4
	C_{cr}	2 1/2	3 3/4	5	6 1/4	7 1/2	8 3/4	10	12 1/2
	C_{min}	1	1 1/2	2	2 1/2	3	3 1/2	4	5
1	f_{min}	0.70	0.70	0.70	0.70	0.70	0.70	0.70	0.70
1 1/2		0.80	0.70						
2		0.90	0.77	0.70					
2 1/2		1.00	0.83	0.75	0.70				
3			0.90	0.80	0.74	0.70			
3 1/2			0.97	0.85	0.78	0.73	0.70		
3 3/4			1.00	0.88	0.80	0.75	0.71		
4				0.90	0.82	0.77	0.73	0.70	
4 1/2				0.95	0.86	0.80	0.76	0.73	
5				1.00	0.90	0.83	0.79	0.75	0.70
5 1/2					0.94	0.87	0.81	0.78	0.72
6					0.98	0.90	0.84	0.80	0.74
6 1/4					1.00	0.92	0.86	0.81	0.75
6 1/2						0.93	0.87	0.83	0.76
7						0.97	0.90	0.85	0.78
7 1/2						1.00	0.93	0.88	0.80
8							0.96	0.90	0.82
8 1/2							0.99	0.93	0.84
8 3/4							1.00	0.94	0.85
10								1.00	0.90
12 1/2									1.00
15									

* See page 13 for an explanation of the load table icons

See Notes Below

Edge Distance Shear (f_c)
(Shear Applied Perpendicular to Edge)



Edge Dist. C_{act} (in.)	Size	1/4	3/8	1/2	5/8	3/4	7/8	1	1 1/4
	C_{cr}	2 1/2	3 3/4	5	6 1/4	7 1/2	8 3/4	10	12 1/2
	C_{min}	1	1 1/2	2	2 1/2	3	3 1/2	4	5
1	f_{min}	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30
1 1/2		0.53	0.30						
2		0.77	0.46	0.30					
2 1/2		1.00	0.61	0.42	0.30				
3			0.77	0.53	0.39	0.30			
3 1/2			0.92	0.65	0.49	0.38	0.30		
3 3/4			1.00	0.71	0.53	0.42	0.33		
4				0.77	0.58	0.46	0.37	0.30	
4 1/2				0.88	0.67	0.53	0.43	0.36	
5				1.00	0.77	0.61	0.50	0.42	0.30
5 1/2					0.86	0.69	0.57	0.48	0.35
6					0.95	0.77	0.63	0.53	0.39
6 1/4					1.00	0.81	0.67	0.56	0.42
6 1/2						0.84	0.70	0.59	0.44
7						0.92	0.77	0.65	0.49
7 1/2						1.00	0.83	0.71	0.53
8							0.90	0.77	0.58
8 1/2							0.97	0.83	0.63
8 3/4							1.00	0.85	0.65
10								1.00	0.77
12 1/2									1.00
15									


1. C_{act} = actual edge distance at which anchor is installed (inches).
2. C_{cr} = critical edge distance for 100% load (inches).
3. C_{min} = minimum edge distance for reduced load (inches).
4. f_c = adjustment factor for allowable load at actual edge distance.
5. f_{cr} = adjustment factor for allowable load at critical edge distance. f_{cr} is always = 1.00.
6. f_{min} = adjustment factor for allowable load at minimum edge distance.
7. $f_c = f_{min} + [(1 - f_{min}) (C_{act} - C_{min}) / (C_{cr} - C_{min})]$.

Load-Adjustment Factors for Reduced Spacing:

Critical spacing is listed in the load tables. No adjustment in load is required when the anchors are spaced at critical spacing. No additional testing has been performed to determine the adjustment factors for spacing dimensions less than those listed in the load tables.

Simpson Strong-Tie® Anchoring and Fastening Systems for Concrete and Masonry

Wedge-All® Technical Information



Load-Adjustment Factors for Carbon-Steel and Stainless-Steel Wedge-All® Anchors in Normal-Weight Concrete: Spacing, Tension Loads

- How to use these charts:
1. The following tables are for reduced spacing.

2. Locate the anchor size to be used for a tension load application.

3. Locate the anchor embedment (E) used for a tension load application.

4. Locate the spacing (S_{act}) at which the anchor is to be installed.

5. The load adjustment factor (f_s) is the intersection of the row and column.

6. Multiply the allowable load by the applicable load adjustment factor.

7. Reduction factors for multiple spacings are multiplied together.

Spacing Tension (f_s)

S _{act} (in.)	Dia.	¼			⅜			½			¾		
	E	1⅞	2⅞		1⅞	2⅞	3⅞	2⅞	3⅞	4⅞	2⅞	4⅞	5⅞
	S _{cr}	1⅞	3⅞	2⅞	3⅞	4⅞		3⅞	4⅞	6⅞	3⅞	6⅞	7⅞
	S _{min}	⅞	1⅞	⅞	1⅞	1⅞	1⅞	1⅞	1⅞	2⅞	1⅞	2⅞	2⅞
	f _{smin}	0.43	0.70	0.43	0.43	0.70	0.43	0.43	0.70	0.43	0.43	0.43	0.70
¾		0.50											
1		0.64		0.48									
1¼		0.79	0.72	0.57			0.47						
1½		0.93	0.76	0.67	0.46		0.54			0.46			
1¾		1.00	0.79	0.76	0.53	0.70	0.61	0.43		0.52			
2			0.83	0.86	0.59	0.73	0.68	0.48		0.57			
2¼			0.87	0.95	0.65	0.75	0.75	0.53	0.70	0.63	0.43		
2½			0.91	1.00	0.72	0.78	0.82	0.57	0.72	0.69	0.47		
2¾			0.94		0.78	0.80	0.89	0.62	0.74	0.74	0.50	0.70	
3			0.98		0.84	0.83	0.96	0.67	0.76	0.80	0.54	0.72	
3½			1.00		0.97	0.88	1.00	0.76	0.79	0.91	0.61	0.75	
4					1.00	0.93		0.86	0.83	1.00	0.68	0.78	
4½						0.98		0.95	0.87		0.75	0.81	
5						1.00		1.00	0.91		0.82	0.84	
6									0.98		0.96	0.90	
7									1.00		1.00	0.96	
> 8												1.00	

*See page 13 for an explanation of the load table icons

See Notes Below

Spacing Tension (f_s)

S _{act} (in.)	Dia.	¾			⅞		1		1¼	
	E	3⅞	5	6⅞	3⅞	7⅞	4⅞	9	5⅞	9⅞
	S _{cr}	4⅞	7	9⅞	5⅞	11	6⅞	12⅞	7⅞	13⅞
	S _{min}	1⅞	2⅞	3⅞	2	4	2⅞	4⅞	2⅞	4⅞
	f _{smin}	0.43	0.43	0.70	0.43	0.70	0.43	0.70	0.43	0.70
2		0.48			0.43					
3		0.67	0.49		0.60		0.54		0.46	
4		0.86	0.62	0.73	0.77	0.70	0.68		0.57	
5		1.00	0.75	0.78	0.94	0.74	0.82	0.72	0.68	0.71
6			0.87	0.83	1.00	0.79	0.96	0.76	0.79	0.74
7			1.00	0.88		0.83	1.00	0.79	0.90	0.78
8				0.93		0.87		0.83	1.00	0.81
9				0.98		0.91		0.87		0.85
10				1.00		0.96		0.90		0.89
11						1.00		0.94		0.92
12								0.98		0.96
13								1.00		0.99
14										1.00

1. E = Embedment depth (inches).

2. S_{act} = actual spacing distance at which anchors are installed (inches).

3. S_{cr} = critical spacing distance for 100% load (inches).

4. S_{min} = minimum spacing distance for reduced load (inches).

5. f_s = adjustment factor for allowable load at actual spacing distance.

6. f_{s,cr} = adjustment factor for allowable load at critical spacing distance.

7. f_{smin} = adjustment factor for allowable load at minimum spacing distance.

8. f_s = f_{smin} + [(1 - f_{smin}) (S_{act} - S_{min}) / (S_{cr} - S_{min})].

Mechanical Anchors

Wedge-All® Technical Information

SIMPSON

Strong-Tie

Load-Adjustment Factors for Carbon-Steel and Stainless-Steel Wedge-All® Anchors in Normal-Weight Concrete: Spacing, Shear Loads

How to use these charts:

1. The following tables are for reduced spacing.

2. Locate the anchor size to be used for a shear load application.

3. Locate the anchor embedment (E) used for a shear load application.

4. Locate the spacing (S_{act}) at which the anchor is to be installed.
5. The load adjustment factor (f_s) is the intersection of the row and column.

6. Multiply the allowable load by the applicable load adjustment factor.

7. Reduction factors for multiple spacings are multiplied together.

Spacing Shear (f_s)



S_{act} (in.)	Dia.	$\frac{1}{4}$		$\frac{3}{8}$			$\frac{1}{2}$			$\frac{3}{4}$		
	E	1½	2½	1¾	2¾	3¾	2¾	3¾	4¾	2¾	4¾	5¾
	S_{cr}	1¾	3¾	2¾	3¾	4¾	3¾	4¾	6¾	3¾	6¾	7¾
	S_{min}	$\frac{5}{8}$	1¾	$\frac{7}{8}$	1¾	1¾	1¾	1¾	2¾	1¾	2¾	2¾
	f_{smin}	0.79	0.79	0.79	0.79	0.79	0.79	0.79	0.79	0.79	0.79	0.79
$\frac{3}{4}$		0.82										
1		0.87		0.81								
1¼		0.92	0.80	0.84			0.80					
1½		0.97	0.83	0.88	0.80		0.83			0.80		
1¾		1.00	0.86	0.91	0.83	0.79	0.86	0.79		0.82		
2			0.88	0.95	0.85	0.81	0.88	0.81		0.84		
2¼			0.91	0.98	0.87	0.83	0.91	0.83	0.79	0.86	0.79	
2½			0.93	1.00	0.90	0.84	0.93	0.84	0.80	0.88	0.80	
2¾			0.96		0.92	0.86	0.96	0.86	0.82	0.91	0.82	0.79
3			0.99		0.94	0.88	0.99	0.88	0.83	0.93	0.83	0.80
3½			1.00		0.99	0.91	1.00	0.91	0.86	0.97	0.86	0.82
4					1.00	0.95		0.95	0.88	1.00	0.88	0.84
4½						0.98		0.98	0.91		0.91	0.86
5						1.00		1.00	0.93		0.93	0.88
6									0.99		0.99	0.93
7									1.00		1.00	0.97
> 8												1.00

*See page 13 for an explanation of the load table icons

See Notes Below


Spacing Shear (f_s)



S_{act} (in.)	Dia.	$\frac{3}{4}$			$\frac{1}{2}$		1		1¼	
	E	3¾	5	6¾	3¾	7¾	4¾	9	5¾	9¾
	S_{cr}	4¾	7	9½	5¾	11	6¾	12¾	7¾	13¾
	S_{min}	1¾	2½	3¾	2	4	2¾	4¾	2¾	4¾
	f_{smin}	0.79	0.79	0.79	0.79	0.79	0.79	0.79	0.79	0.79
2		0.81			0.79					
3		0.88	0.81		0.85		0.83		0.80	
4		0.95	0.86	0.81	0.91	0.79	0.88		0.84	
5		1.00	0.91	0.85	0.98	0.82	0.93	0.80	0.88	0.80
6			0.95	0.88	1.00	0.85	0.99	0.83	0.92	0.82
7			1.00	0.91		0.88	1.00	0.85	0.96	0.85
8				0.95		0.91		0.88	1.00	0.87
9				0.98		0.94		0.91		0.90
10				1.00		0.97		0.93		0.92
11						1.00		0.96		0.94
12								0.98		0.97
13								1.00		0.99
14										1.00

1. E = Embedment depth (inches).
2. S_{act} = actual spacing distance at which anchors are installed (inches).
3. S_{cr} = critical spacing distance for 100% load (inches).
4. S_{min} = minimum spacing distance for reduced load (inches).
5. f_s = adjustment factor for allowable load at actual spacing distance.
6. f_{scr} = adjustment factor for allowable load at critical spacing distance.
7. f_{smin} = adjustment factor for allowable load at minimum spacing distance.
8. $f_s = f_{smin} + [(1 - f_{smin}) (S_{act} - S_{min}) / (S_{cr} - S_{min})]$.

Mechanical Anchors




JOB# 0100571.00 SHEET No OF 10
 PROJECT NAME B Cycle
 SUBJECT Foundation slab
 CALCULATED BY SG DATE 11/12/12
 CHECKED BY DATE

Slab overturning - 6'-0" x 6'-6" x 5" slab

$$M_{OT} = 2203 \text{ ft-lb}$$

$$M_{resisting} = (0.6)(150)(6)(6.5)(0.42)(6/2) = 4388 \text{ ft-lb} \quad \text{O.K.}$$

Check flexure in unreinforced slab. Assume station is placed eccentrically on slab



$$M_{OT} = \underset{\substack{\uparrow \\ \text{wind}}}{2203 \text{ ft-lb}} + \underset{\substack{\uparrow \\ \text{gravity}}}{439 \text{ lb}} (1.875) = 3026 \text{ ft-lb (service)}$$


$$P = \underset{\substack{\uparrow \\ \text{floating}}}{(150)(6)(6.5)(0.42)} = 2438 \text{ lb} + \underset{\substack{\uparrow \\ \text{station}}}{439 \text{ lb}} = 2877 \text{ lb}$$

$$e = M/P = 3026/2877 = 1.05 \text{ ft} \rightarrow \text{outside of middle third}$$

$$m = 3 - 1.05 = 1.95'$$

$$f_b = 2877/m = 2(2877)/3(6.5)(1.95) = 151 \text{ psf} \ll 2000 \text{ psf} \quad \text{O.K.}$$

$$f_{b, \text{ultimate}} = 151/0.6 = 252 \text{ psf}$$



At face of support $f_{a, \text{gross}} = 170 \text{ psf}$, $f_{a, \text{net}} = 170 - 1.2(62.5) = 95 \text{ psf}$

$$M_u = (0.95)(6.5)(3.94/2)(3.94/3) = 1.60 \text{ k-ft}$$

$$\phi M_n = (0.65)(5)(11)(\sqrt{3000})(78)(5-2)^2 / 12000 = 1.74 \text{ k-ft} \quad M_u < \phi M_n$$